# **CHAPTER 13**

# **Heating Systems**

# **Learning Objectives**

Upon completion of this chapter, students will be able to:

- 1. Identify and explain the operation of forced air furnace components
- 2. Install furnaces according to manufacturer specifications and CSA B149.1
- 3. Understand furnace control sequences and troubleshoot control problems
- 4. Design and install hydronic heating systems with proper components
- 5. Configure radiant heating systems for various applications
- 6. Integrate dual fuel heat pump systems with gas furnaces
- 7. Perform complete commissioning procedures on heating systems
- 8. Apply systematic troubleshooting techniques to diagnose heating problems
- 9. Calculate heating loads and equipment sizing
- 10. Document installation and service work properly

## 13.1 Forced Air Furnaces

Forced air furnaces are the most common residential heating systems in Canada, providing efficient heat distribution through ductwork.

## **System Components**

Understanding each component's function is essential for proper installation and service.

## **Heat Exchanger**

## **Primary Heat Exchanger:**

- Separates combustion products from circulated air
- Constructed of aluminized steel, stainless steel, or cast iron
- Transfers combustion heat to supply air
- Must maintain separation integrity
- Life expectancy: 15-30 years

#### **Types of Heat Exchangers:**

1. Tubular:

- o Individual tubes or cylinders
- o Serpentine design common
- Good heat transfer
- Moderate cost
- Easy to manufacture

## 2. Clamshell:

- Stamped steel sections
- Welded or crimped seams
- Compact design
- Lower cost
- Common in older units

#### 3. **Drum:**

- Cylindrical design
- o Heavy gauge steel
- o Durable construction
- Higher cost
- Less common today

## **Secondary Heat Exchanger (Condensing):**

- Stainless steel construction (typically 439SS or 29-4C)
- Extracts latent heat from flue gases
- Produces condensate
- Increases efficiency to 90%+
- Requires condensate management

## **Burner Assembly**

## **Components:**

- Burner tubes or ribbon burners
- Orifices (spuds)
- Manifold
- Gas valve
- Crossover/carryover tubes

## **Burner Types:**

#### 1. In-shot Burners:

- Most common design
- o Gas and primary air mix in venturi
- Individual burner tubes
- o Natural draft or induced draft
- o 30,000-40,000 BTU per burner typical

#### 2. Ribbon/Matrix Burners:

Metal fiber mat design

- o Large surface area
- o Lower NOx emissions
- o Quieter operation
- Higher cost

#### 3. Pre-mix Burners:

- o Gas and air mixed before combustion
- Precise control required
- Used in modulating systems
- o Higher efficiency potential
- Complex controls

## **Blower Assembly**

## **Blower Types:**

## 1. PSC (Permanent Split Capacitor):

- o Single-speed or multi-speed
- Simple control
- Lower cost
- o 60-70% electrical efficiency
- Speed taps for adjustment

## 2. ECM (Electronically Commutated Motor):

- Variable speed capability
- o Constant airflow delivery
- o 80-85% electrical efficiency
- Soft start/stop
- Advanced diagnostics

## **Blower Specifications:**

- CFM rating (typically 400 CFM per ton)
- Static pressure capability (0.5" 1.0" W.C.)
- Horsepower (1/3 to 1 HP residential)
- Voltage (120V or 240V)
- Speed options

## **Control Systems**

## **Integrated Furnace Control (IFC):**

- Microprocessor-based
- Manages all furnace operations
- Diagnostic capabilities
- Safety monitoring
- Communication protocols

#### **Control Functions:**

- Ignition sequence
- Blower operation
- Safety monitoring
- Fault detection
- User interface

## **Airflow Principles**

Proper airflow is critical for comfort and equipment longevity.

## **Airflow Requirements**

## **Design Parameters:**

- Heating: 400 CFM per ton typical
- Cooling: 350-450 CFM per ton
- Temperature rise: 30-70°F (check nameplate)
- External static pressure: 0.5" W.C. maximum typical

## **Calculating Required Airflow:**

```
CFM = Output BTU/hr / (1.08 \times Temperature Rise)
```

## **Example:**

- 80,000 BTU/hr output
- 50°F temperature rise
- CFM =  $80,000 / (1.08 \times 50) = 1,481$  CFM

#### **Static Pressure**

## **Components of Static Pressure:**

# Component Typical Pressure Drop Clean filter 0.10" - 0.15" W.C. Dirty filter 0.25" - 0.50" W.C. Supply ductwork 0.05" - 0.15" W.C. Return ductwork 0.05" - 0.10" W.C. Registers/grilles 0.03" - 0.05" W.C. Cooling coil 0.20" - 0.30" W.C.

## **Measuring Static Pressure:**

- 1. Drill test holes in supply and return plenums
- 2. Insert manometer probes
- 3. Measure with system running
- 4. Total External Static = Supply + Return (absolute values)
- 5. Compare to blower capability

## **Duct Design Considerations**

## **Proper Sizing:**

- Use ACCA Manual D or equivalent
- Account for all fittings
- Consider future additions
- Balance supply and return

#### **Common Problems:**

- Undersized returns (most common)
- Excessive elbows
- Flex duct compression
- Poor transitions
- Inadequate registers

## **Heat Exchanger Types**

Different heat exchanger designs affect efficiency and application.

## **Primary Heat Exchangers**

#### **Aluminized Steel:**

- Most common material
- Good corrosion resistance
- Moderate cost
- 15-20 year typical life
- Aluminum coating on steel

#### **Stainless Steel:**

- Superior corrosion resistance
- Higher cost
- 20-30+ year life
- Better for condensing
- Various grades (409, 439, 316L)

## **Cast Iron:**

- Excellent durability
- High thermal mass
- Slow response time
- Heavy weight
- Mainly boilers now

## **Secondary Heat Exchangers**

## **Purpose:**

- Extract latent heat
- Cool flue gases below dew point
- Increase efficiency 10-15%
- Produce condensate

#### **Construction:**

- Stainless steel required
- Finned tubes common
- Counter-flow design
- Condensate collection
- Corrosion resistant

## Condensing vs. Non-Condensing

Understanding the differences helps with selection and service.

## **Non-Condensing Furnaces**

#### **Characteristics:**

- 78-83% AFUE typical
- Exhaust temperature 300-500°F
- No condensate production
- Natural or induced draft
- Type B venting typical

## Advantages:

- Lower initial cost
- Simple installation
- No condensate management
- Proven technology
- Easy service

## **Disadvantages:**

- Lower efficiency
- Higher operating cost
- Heat lost in exhaust
- May require chimney

## **Condensing Furnaces**

#### **Characteristics:**

- 90-98% AFUE
- Exhaust temperature 100-140°F
- Produces acidic condensate
- Positive pressure venting
- PVC venting typical

## **Advantages:**

- High efficiency
- Lower operating costs
- Utility rebates available
- Flexible venting
- Quieter operation

## **Disadvantages:**

- Higher initial cost
- Condensate management
- More complex
- Freeze protection needed
- Regular maintenance critical

## **Efficiency Ratings**

Understanding efficiency metrics helps with equipment selection.

## **AFUE (Annual Fuel Utilization Efficiency)**

#### **Definition:**

- Ratio of annual heat output to annual fuel input
- Expressed as percentage
- Includes cycling losses
- Seasonal average

## **Categories:**

## Efficiency Level AFUE Range Technology

Standard 78-80%	Non-condensing
-----------------	----------------

Mid-efficiency 80-83% Non-condensing, improved

High-efficiency 90-98% Condensing

Ultra-high 95-98% Modulating condensing

## **Steady-State Efficiency**

#### **Definition:**

- Efficiency during continuous operation
- Higher than AFUE
- Doesn't include cycling losses
- Laboratory measurement

## **Typical Values:**

• Non-condensing: 80-85%

• Condensing: 92-98%

• Difference from AFUE: 2-5%

## Input vs. Output

## **Understanding Ratings:**

• Input: Gas consumed (BTU/hr)

• Output: Heat delivered (BTU/hr)

• Output = Input × Efficiency

## **Example:**

• Input: 100,000 BTU/hr

• Efficiency: 95%

• Output: 95,000 BTU/hr

## **Multi-Stage and Modulating Systems**

Advanced systems provide improved comfort and efficiency.

## **Two-Stage Furnaces**

## **Operation:**

• Low fire: 40-70% capacity

• High fire: 100% capacity

- Automatic staging
- Longer run times
- Better comfort

#### **Benefits:**

- Quieter operation on low fire
- Better temperature control
- Improved humidity control
- Higher efficiency
- Reduced cycling

#### **Control Methods:**

- Two-stage thermostat
- Timed staging
- Outdoor temperature
- Smart controls

## **Modulating Furnaces**

## **Operation:**

- Variable capacity 40-100%
- Continuous adjustment
- Matches heat loss precisely
- Advanced controls required

## **Components:**

- Modulating gas valve
- Variable-speed blower
- Advanced control board
- Communicating thermostat
- Multiple sensors

## **Benefits:**

- Optimal comfort
- Maximum efficiency
- Minimal temperature swing
- Quiet operation
- Superior humidity control

#### **Modulation Control:**

- Room temperature feedback
- Supply air temperature
- Return air temperature
- Outdoor temperature
- PID control algorithms

## 13.2 Furnace Installation

Proper installation ensures safe operation, optimal performance, and code compliance.

## **Location Requirements**

Selecting the appropriate location affects performance and serviceability.

## **Code Requirements**

## **CSA B149.1 Specifications:**

- Not in sleeping quarters
- Not in bathrooms
- Not in clothes closets
- Not blocking exits
- Accessible for service

## **Exceptions:**

- Direct vent furnaces in bedrooms (some jurisdictions)
- Sealed combustion units
- Special occupancies
- With additional protection

## **Preferred Locations**

#### **Basement Installation:**

- Central location ideal
- Easy duct distribution
- Service accessibility
- Combustion air available
- Condensate drainage simple

## **Utility Room:**

Dedicated space

- Sound isolation
- Good for main floor
- Requires proper sizing
- Door requirements

#### **Attic Installation:**

- Saves floor space
- Special requirements apply
- Overflow protection needed
- Access platform required
- Insulation considerations

## **Crawl Space:**

- Horizontal furnaces available
- Moisture concerns
- Access requirements
- Support requirements
- Special venting needs

## **Clearances per Code**

Maintaining proper clearances ensures safety and service access.

#### **Minimum Clearances**

## **Standard Requirements:**

## **Location Minimum Clearance**

Front (service) 24 inches

Sides 1 inch (or per manufacturer)

Back 0 inches typical

Top (plenum) 1 inch

Vent connector 6 inches (single wall)
Combustibles Per manufacturer

#### **Alcove Installation:**

- Minimum width: Furnace + 3 inches
- Minimum depth: Per manufacturer
- Door if required: Louvered
- Combustion air provisions

#### **Service Clearances**

## **Access Requirements:**

- Burner removal space
- Blower service access
- Control compartment access
- Filter replacement clearance
- Minimum 30" × 30" work space

## **Platform Requirements:**

- Attic installations: 30" × 30" minimum
- Load capacity: 200 lbs minimum
- Permanent light required
- Switch at entry
- Walkway if needed

## **Return Air Considerations**

Proper return air design ensures adequate airflow and comfort.

## **Sizing Requirements**

#### **Calculation Method:**

```
Return Area (sq in) = CFM / Face Velocity Face Velocity = 400-600 FPM typical
```

## **Example:**

- Required CFM: 1,200
- Face velocity: 500 FPM
- Area =  $(1,200 / 500) \times 144 = 346$  sq in
- Duct size: 18" × 20" or equivalent

#### **Return Air Locations**

## **Recommended Placement:**

- Central location
- High on walls for cooling
- Low for heating only
- Away from supply registers
- Not in bathrooms/kitchens

#### **Multiple Returns:**

- Improved air circulation
- Better comfort
- Reduced noise
- Lower velocity
- Balanced pressures

#### **Combustion Air from Returns**

## When NOT Permitted:

- Solid fuel appliances present
- Commercial kitchens
- Contaminated air possible
- Paint booths
- Chemical storage areas

## **Requirements When Allowed:**

- Volume calculations per code
- No exhaust fans impact
- Sealed returns
- No garage air
- Clean environment

## **Filter Access**

Proper filter installation and access ensures maintenance.

## **Filter Locations**

## **Options:**

#### 1. Furnace Cabinet:

- Standard location
- Easy replacement
- Size limitations
- Check clearance

## 2. Return Air Drop:

- Larger filters possible
- Better accessibility
- Quieter operation
- o Higher capacity

## 3. Return Grille:

- Most accessible
- o Multiple locations possible
- Size flexibility

## o Customer friendly

## **Filter Types and Ratings**

## **MERV Ratings:**

<b>MERV Rating</b>	<b>Efficiency</b>	<b>Application</b>
1-4	<20%	Basic protection
5-8	20-85%	Standard residential
9-12	85-95%	Better air quality
13-16	95-99%+	Hospital/clean room

## **Pressure Drop Considerations:**

- Higher MERV = Higher restriction
- Size appropriately
- Check blower capability
- Monitor static pressure

## **Gas Piping Connections**

Proper gas connections ensure adequate supply and safety.

## **Pipe Sizing**

## **Determining Size:**

- 1. Calculate total BTU load
- 2. Measure pipe length
- 3. Use CSA B149.1 tables
- 4. Account for fittings
- 5. Verify at meter

## **Example Calculation:**

Furnace input: 100,000 BTU/hr
Distance from meter: 30 feet
From table: 3/4" pipe required

## **Connection Requirements**

## **Installation Steps:**

- 1. Install shut-off valve within 6 feet
- 2. Install union for service

- 3. Install sediment trap (drip leg)
- 4. Use approved joint compound
- 5. Pressure test at 10 PSIG
- 6. Check for leaks

## **Component Details:**

- Manual shut-off: Ball valve required
- Union: For equipment removal
- Sediment trap: 3" minimum nipple
- Flex connector: Listed for gas, 3 feet maximum

## **Electrical Connections**

Proper electrical installation ensures safe operation.

## **Power Requirements**

## **Voltage Options:**

- 120VAC most common
- 240VAC for larger units
- 15 or 20 amp circuit typical
- Dedicated circuit recommended

## Wire Sizing:

- Based on furnace nameplate
- Maximum circuit ampacity
- 14 AWG minimum typically
- 12 AWG for 20 amp circuit

## **Control Wiring**

## **Thermostat Wiring:**

## **Terminal Function Wire Color (typical)**

R 24V power Red
C Common Blue
W Heat call White
Y Cool call Yellow
G Fan Green

## **Installation Requirements:**

- 18 AWG thermostat wire minimum
- Separate from line voltage
- Proper routing
- Strain relief
- Color coding

## **Combustion Air Provisions**

Adequate combustion air ensures safe, efficient operation.

## **Air Requirements**

## **Calculation Methods:**

- 1. Standard Method:
  - o 1 sq in per 4,000 BTU/hr (all air from inside)
  - o 1 sq in per 4,000 BTU/hr each opening (outside air)
- 2. Known Air Infiltration:
  - o 0.40 ACH or greater: No additional air
  - o Less than 0.40 ACH: Provide outside air

## **Example:**

- 100,000 BTU/hr furnace
- From inside: 100,000/4,000 = 25 sq in
- Two openings: 12.5 sq in each minimum

#### **Outdoor Air Methods**

## **Two-Opening Method:**

- One within 12" of ceiling
- One within 12" of floor
- Size per calculations
- Proper screening
- Dampers not permitted

## **Single-Opening Method:**

- Direct to outdoors
- 1 sq in per 3,000 BTU/hr
- Minimum dimension requirements
- Located properly

## **Venting Installation**

Proper venting ensures safe removal of combustion products.

## **Non-Condensing Furnace Venting**

## **Type B Vent:**

- 1" clearance to combustibles
- Proper support spacing
- Correct termination height
- Listed cap required

## **Connection Requirements:**

- Minimum 1/4" per foot rise
- Maximum horizontal per tables
- Secure all joints
- Fire stops required

## **Condensing Furnace Venting**

## **PVC/CPVC Venting:**

- Follow manufacturer exactly
- Proper support (3-4 feet)
- Slope to furnace (1/4" per foot)
- Prime and cement joints
- Termination clearances

## **Installation Steps:**

- 1. Plan route
- 2. Calculate equivalent length
- 3. Install supports
- 4. Assemble with proper cement
- 5. Install termination kit
- 6. Check slope throughout

# 13.3 Furnace Controls and Sequences

Understanding control operation is essential for installation and troubleshooting.

## **Thermostat Operation**

Thermostats initiate heating cycles and control comfort levels.

## **Types of Thermostats**

## **Mechanical Thermostats:**

- Bimetallic element
- Mercury switch (older)
- Simple operation
- No power required
- Heat anticipator adjustment

## **Electronic Thermostats:**

- Thermistor sensing
- Digital display
- Precise control (±1°F)
- Battery or hardwired
- Multiple features

## **Smart Thermostats:**

- WiFi connectivity
- Learning algorithms
- Remote access
- Energy reporting
- Integration capabilities

## **Thermostat Wiring and Signals**

## **Standard Terminals:**

Terminal	Function	Operation
R/Rc	Power from transformer	24VAC continuous
W/W1	First stage heat	Closes on heat call
W2	Second stage heat	Two-stage systems
Y/Y1	First stage cooling	A/C compressor
Y2	Second stage cooling	Two-stage A/C
G	Fan	Continuous fan
C	Common	Complete circuit

## **Anticipator Settings:**

- Mechanical only
- Matches gas valve current
- Typically 0.4-0.6 amps

- Affects cycle rate
- Proper setting critical

## **Blower Control Sequences**

Blower operation varies with system type and configuration.

#### **PSC Motor Control**

## **Heating Sequence:**

- 1. Thermostat calls for heat
- 2. Burner ignites
- 3. Time delay (30-45 seconds)
- 4. Blower starts on heat speed
- 5. Heating cycle continues
- 6. Thermostat satisfied
- 7. Burner stops
- 8. Blower continues (45-90 seconds)
- 9. Blower stops

## **Speed Selection:**

- Low: Continuous fan
- Medium-Low: Heating
- Medium-High: Cooling (if equipped)
- High: Emergency heat

## **ECM Motor Control**

## **Constant CFM Operation:**

- Motor adjusts to maintain CFM
- Compensates for filter loading
- Multiple comfort profiles
- Soft start/stop
- Delay profiles programmable

## **Operating Modes:**

Mode	<b>CFM Setting</b>	Ramp Time
Heating	100% programmed	30 seconds
Cooling	Adjusted for humidity	30 seconds
Continuous	50% typical	60 seconds
Dehumidification	80% cooling	Variable

## **Limit Switch Operation**

Limit switches prevent overheating and ensure safety.

## **Primary Limit**

## **Function:**

- Monitors heat exchanger temperature
- Opens at high temperature
- Shuts off gas valve
- Auto or manual reset

## **Typical Settings:**

Open: 160-200°F
Close: 140-180°F
Differential: 20-25°F
Location: Supply plenum

## **Auxiliary Limits**

## **Secondary Limit:**

- Backup protection
- Manual reset typical
- Higher setpoint
- Series with primary

#### **Roll-Out Switch:**

- Detects flame roll-out
- Located near burners
- Manual or auto reset
- Multiple switches possible

## **Ignition Control Modules**

Modern ignition systems provide reliable, safe operation.

## **Hot Surface Ignition (HSI)**

## **Sequence of Operation:**

- 1. Thermostat call
- 2. Inducer starts (if present)

- 3. Pressure switch closes
- 4. Ignitor energizes (30-45 seconds)
- 5. Gas valve opens
- 6. Flame sensor detects flame
- 7. Ignitor de-energizes
- 8. Main burner continues

## **Ignitor Types:**

- Silicon carbide (older)
- Silicon nitride (current)
- 120V or 24V
- 3-5 year typical life

## **Direct Spark Ignition (DSI)**

## **Operating Sequence:**

- 1. Call for heat
- 2. Spark generation starts
- 3. Pilot valve opens (if used)
- 4. Main valve opens
- 5. Flame detected
- 6. Spark stops
- 7. Continuous monitoring

## **Components:**

- Ignition module
- Spark electrode
- Flame sensor (may be combined)
- High voltage cable

## **Integrated Furnace Controls**

Modern furnaces use sophisticated integrated controls.

#### **IFC Features**

## **Capabilities:**

- Complete sequence control
- Diagnostic LEDs
- Fault history
- Blower speed control
- Safety monitoring

## • Communication ability

## **Typical Inputs:**

InputFunctionThermostatHeat/cool demandPressure switchDraft provingLimit switchesOverheat protectionFlame sensorFlame presence

Roll-out switches Safety

## **Outputs:**

Output Function
Inducer motor Draft creation
Ignitor Flame ignition
Gas valve Fuel control
Blower motor Air circulation
Humidifier Humidity control

## **Diagnostic Features**

## **LED Flash Codes:**

Code	Meaning	Action
1 flash	Normal operation	None
2 flashes	Pressure switch stuck closed	Check switch
3 flashes	Pressure switch open	Check venting
4 flashes	Open high limit	Check airflow
5 flashes	Flame failure	Check gas/ignition
6 flashes	Roll-out switch	Reset and investigate
7 flashes	Low flame signal	Clean sensor

## **Communication Protocols**

Advanced systems use digital communication.

## **Types of Communication**

## **Proprietary Systems:**

- Manufacturer specific
- Full feature access
- Diagnostic capability
- Limited compatibility
- Examples: Carrier Infinity, Trane ComfortLink

#### **Standard Protocols:**

- BACnet
- Modbus
- LON
- OpenTherm
- Wider compatibility

## **Communicating Components**

## **System Elements:**

- Thermostat (user interface)
- Furnace control
- A/C or heat pump
- Zoning system
- Humidifier
- Air cleaner

## **Information Exchanged:**

- Temperature setpoints
- Operating status
- Fault codes
- Energy consumption
- Maintenance reminders
- Weather data

# 13.4 Hydronic Heating Systems

Hydronic systems use hot water to distribute heat through piping to terminal units.

## **Hot Water Boilers**

Boilers heat water for distribution through the heating system.

## **Boiler Types**

#### **Fire-Tube Boilers:**

- Hot gases pass through tubes
- Water surrounds tubes
- Cast iron or steel
- High water content
- Slower response

## **Water-Tube Boilers:**

- Water in tubes
- Hot gases surround tubes
- Faster response
- Lower water content
- Higher efficiency possible

## **Condensing Boilers:**

- Aluminum or stainless steel
- 90-98% efficiency
- Low water content
- Fast response
- Requires condensate management

## **Construction Materials**

#### **Cast Iron:**

- Sectional construction
- Long life (30+ years)
- Resistant to thermal shock
- Heavy weight
- Slow response time

## **Steel:**

- Welded construction
- Lighter than cast iron
- Faster response
- Prone to corrosion
- 15-25 year life typical

## **Aluminum/Stainless:**

- Used in condensing units
- Corrosion resistant

- Light weight
- High efficiency
- Sensitive to water quality

## **System Components**

Hydronic systems require various components for proper operation.

## **Circulators (Pumps)**

## **Types:**

#### 1. Wet Rotor:

- Water lubricated
- Quiet operation
- o Maintenance free
- Limited head capability
- Residential standard

## 2. Dry Rotor:

- External motor
- Higher head capability
- o Requires maintenance
- Commercial applications
- Louder operation

## **Sizing Considerations:**

```
GPM = BTU/hr / (\Delta T \times 500)
```

Where  $\Delta T =$  Temperature drop (typically 20°F)

## **Example:**

- Heat load: 50,000 BTU/hr
- Temperature drop: 20°F
- GPM =  $50,000 / (20 \times 500) = 5$  GPM

## **Expansion Tanks**

#### **Function:**

- Accommodate water expansion
- Maintain system pressure
- Prevent relief valve discharge
- Air elimination point

## **Types:**

## 1. Steel Compression Tank:

- Air cushion above water
- o Requires air control
- o Larger size
- o Lower cost
- o Maintenance required

## 2. Diaphragm Tank:

- o Rubber diaphragm separation
- o Pre-charged with air
- o Smaller size
- No air absorption
- o Maintenance free

## Sizing:

Tank Volume = System Volume × Expansion Factor × Safety Factor

## **Typical Sizes:**

- Residential: 2-5 gallons
- Light commercial: 5-15 gallons
- Based on system volume
- Temperature range considered

#### **Zone Valves**

## **Purpose:**

- Control flow to zones
- Individual temperature control
- Energy savings
- Comfort improvement

## **Types:**

## 1. Two-Way Valves:

- On/off control
- Motorized actuator
- o Spring return or power open/close
- o 24V typical

## 2. Three-Way Valves:

- o Diverting or mixing
- o Continuous flow
- Temperature control

#### Manual or automatic

#### **Installation:**

- Proper flow direction
- Accessible location
- Wire to zone controller
- Manual override feature
- Isolation valves recommended

## **Piping Configurations**

Different piping arrangements suit various applications.

## **Series Loop**

## **Characteristics:**

- Simplest system
- Single path for water
- No zone control
- Lowest cost
- Temperature drops through loop

## **Applications:**

- Single zone
- Small homes
- Garages
- Low budget

## **One-Pipe System**

#### **Features:**

- Main loop with branches
- Special tees required
- Some temperature drop
- Moderate cost
- Limited zoning

## **Monoflo Tees:**

- Create pressure differential
- Force flow through radiators
- Proper sizing critical

• Specific installation orientation

## **Two-Pipe Direct Return**

#### **Characteristics:**

- Separate supply and return
- Parallel flow paths
- Better temperature control
- Higher cost
- Easier balancing

## **Balancing Required:**

- Closest radiators favor flow
- Balancing valves needed
- Time-consuming setup
- Better comfort

## **Two-Pipe Reverse Return**

#### **Features:**

- Equal pipe lengths
- Self-balancing
- Highest material cost
- Best performance
- Professional preference

## **Design Principle:**

- First supplied, last returned
- Equal resistance paths
- Minimal balancing needed
- Uniform heating

## **Temperature Controls**

Precise temperature control ensures comfort and efficiency.

## **Aquastat Controls**

#### **Functions:**

- Maintain boiler temperature
- Control circulator operation

- Provide high limit protection
- Enable/disable burner

## **Types:**

- 1. Single Aquastat:
  - o High limit only
  - Simple control
  - Constant circulation
  - Lower cost

## 2. Triple Aquastat:

- o High limit
- o Low limit
- o Differential control
- o Maintains minimum temperature

## **Settings Example:**

High limit: 180-200°F
Low limit: 140-160°F
Differential: 10-15°F

#### **Outdoor Reset Controls**

## **Purpose:**

- Adjust water temperature with outdoor temperature
- Improve efficiency
- Enhance comfort
- Reduce cycling

## **Operation:**

- Sensor measures outdoor temperature
- Controller calculates required water temperature
- Mixing valve or boiler modulation
- Continuous adjustment

## **Reset Curve:**

- Design temperature points
- Slope adjustment
- Parallel shift capability
- Building-specific tuning

## **Boiler Installation Requirements**

Proper installation ensures safe, efficient operation.

## **Location Requirements**

## **Code Specifications:**

- Not in sleeping rooms
- Not in bathrooms
- Not in closets
- Adequate clearances
- Service access

#### **Mechanical Room:**

- Preferred location
- Combustion air provisions
- Drainage available
- Electrical supply
- Ventilation required

## **Piping Connections**

## **Near Boiler Piping:**

## 1. Supply Side:

- o Pressure relief valve
- Air eliminator
- o Expansion tank connection
- o Temperature/pressure gauge
- Isolation valve

## 2. Return Side:

- Circulator
- o Fill valve
- o Backflow preventer
- o Drain valve
- Strainer

## **Installation Sequence:**

- 1. Position boiler
- 2. Install relief valve
- 3. Connect expansion tank
- 4. Install circulator
- 5. Connect zones
- 6. Fill and purge system
- 7. Test operation

## **CSA B149.1 Specific Requirements for Boilers**

Code requirements ensure safety and proper installation.

## **Relief Valve Requirements**

## **Specifications:**

- ASME rated
- Set pressure  $\leq 30$  PSI residential
- Capacity  $\geq$  boiler input
- No valve between boiler and relief
- Discharge piped to safe location

#### **Low Water Cutoff**

## When Required:

- Steam boilers (always)
- Hot water over 400,000 BTU/hr
- Cast iron boilers recommended
- Manufacturer requirement

## **Types:**

- Float type
- Probe type
- Flow switch
- Manual reset available

## **Combustion Air**

## **Requirements:**

- Same as furnaces
- Mechanical room considerations
- Louvers sized properly
- Direct vent option
- No dampers permitted

# 13.5 Radiant Heating

Radiant heating provides comfort through infrared radiation rather than air movement.

## **In-Floor Heating Systems**

In-floor radiant provides even, comfortable heat distribution.

## **System Design**

## **Heat Output:**

- 25-35 BTU/hr/sq ft typical
- Based on floor construction
- Surface temperature limits
- 85°F maximum floor temperature

## **Tubing Layout:**

## 1. Serpentine Pattern:

- Simple installation
- o Temperature variation
- Good for small areas
- Single path

## 2. Reverse Return:

- o Balanced temperatures
- o Even heat distribution
- o More complex
- o Preferred method

## **Spacing:**

- 6" on center: High heat areas
- 9" on center: Standard
- 12" on center: Low heat areas
- Closer at perimeter

## **Installation Methods**

#### **Concrete Slab:**

- Tubing tied to wire mesh
- 2" concrete cover minimum
- Insulation below essential
- Edge insulation required
- Thermal mass benefit

## Thin Slab (Overpour):

• 1.5" lightweight concrete

- Over existing floor
- Faster response
- Less weight
- Special additives used

## **Staple-Up:**

- Under subfloor installation
- Aluminum heat transfer plates
- Insulation below
- Access required
- Lower output

## **Suspended Tube:**

- Between joists
- No floor contact
- Lowest output
- Easiest retrofit
- Requires higher water temperature

## **Materials and Components**

## **Tubing Types:**

## 1. PEX (Cross-linked Polyethylene):

- Most common
- o Flexible
- o 25-year warranty typical
- Various connection methods
- o Temperature rating: 200°F

## 2. PERT (Polyethylene Raised Temperature):

- Similar to PEX
- No cross-linking
- o Repairable
- Lower cost
- Good flexibility

## **Manifolds:**

- Flow balancing valves
- Individual loop control
- Temperature gauges
- Air vents
- Isolation valves

## **Panel Radiators**

Modern panel radiators provide efficient space heating.

## **Types**

## **Steel Panel Radiators:**

- Single or double panel
- With or without convectors
- Wall or floor mounted
- Various sizes
- Painted or stainless finish

## **Cast Iron Radiators:**

- Traditional appearance
- High thermal mass
- Slow response
- Decorative options
- Refurbished units available

## **Sizing**

## **Heat Output Factors:**

- Water temperature
- Room temperature
- Radiator size
- Air flow across unit

## **Calculation:**

```
Output = Surface Area \times U-value \times \DeltaT
```

## **Typical Outputs:**

- 150-200 BTU/hr per sq ft
- At 180°F water temperature
- 70°F room temperature

#### Installation

## **Mounting:**

• Wall brackets required

- Level installation
- Clearances maintained
- Behind furniture avoided
- Under windows preferred

## Piping:

- Thermostatic radiator valves
- Balance valves
- Air vents
- Flexible connections
- Proper support

## **Unit Heaters**

Unit heaters provide localized heating for commercial/industrial spaces.

## **Types**

## **Horizontal Unit Heaters:**

- Ceiling mounted
- Downward discharge
- Wide coverage
- Various sizes
- 10,000-400,000 BTU/hr

## **Vertical Unit Heaters:**

- Floor or wall mounted
- Upward discharge
- Compact design
- Good for doorways
- Destratification capable

## **Cabinet Unit Heaters:**

- Attractive enclosure
- Wall or ceiling mount
- Quiet operation
- Residential appearance
- Filtered air

## **Applications**

## **Typical Uses:**

- Garages
- Warehouses
- Workshops
- Entry vestibules
- Loading docks

## **Advantages:**

- Quick heat
- Spot heating
- Low installation cost
- Individual control
- Simple maintenance

## **Installation Considerations**

Proper installation ensures optimal performance.

## **Piping Design**

## Flow Rates:

- Calculate based on heat load
- Size pipes accordingly
- Consider pressure drop
- Velocity limits (4 fps typical)

## **Expansion Compensation:**

- Expansion loops
- Flexible connections
- Swing joints
- Proper anchoring
- Allow for movement

## **Controls**

#### **Zone Control:**

- Individual thermostats
- Zone valves or pumps
- Outdoor reset
- Time scheduling
- Setback capability

## **Mixing Valves:**

- Protect floor surfaces
- Maintain safe temperatures
- Manual or automatic
- Three-way or four-way
- Outdoor reset capable

# **Control Strategies**

Effective control maximizes comfort and efficiency.

#### **Constant Circulation**

#### **Method:**

- Pump runs continuously
- Temperature varies
- Even heat distribution
- No on/off cycling

#### **Benefits:**

- Stable temperatures
- Quiet operation
- Reduced expansion noise
- Even floor temperatures

## **Intermittent Operation**

#### **Method:**

- Pump cycles with demand
- Fixed water temperature
- Traditional control
- Simple implementation

#### **Considerations:**

- Temperature swings
- Expansion noise
- Energy savings questionable
- Simpler controls

#### **Outdoor Reset**

#### **Benefits:**

- Optimal efficiency
- Improved comfort
- Reduced cycling
- Lower return temperatures
- Condensing boiler compatible

#### **Implementation:**

- Outdoor sensor required
- Reset controller
- Mixing valve or modulation
- Proper curve selection
- Fine-tuning period

# 13.6 Heat Pump Systems (Dual Fuel)

Dual fuel systems combine heat pumps with gas furnaces for optimal efficiency.

# **Integration with Gas Furnaces**

Proper integration ensures seamless operation between heating sources.

#### **System Configuration**

#### **Components:**

- Heat pump outdoor unit
- Gas furnace indoor
- Dual fuel thermostat
- Outdoor temperature sensor
- Control integration

## **Operating Modes:**

#### 1. Heat Pump Only:

- Above balance point
- Most efficient
- o Typical above 30-40°F
- Electric heating

#### 2. **Dual Operation:**

- Near balance point
- Heat pump primary
- Furnace supplements
- Improved capacity

#### 3. Furnace Only:

- o Below balance point
- During defrost
- o Emergency heat
- Coldest weather

## **Control Wiring**

#### **Terminal Connections:**

Terminal	Function	Operation
O/B	Reversing valve	Heat/cool changeover
Y	Compressor	Heat pump call
W2/AUX	Auxiliary heat	Gas furnace
E	Emergency heat	Furnace only
C	Common	24V return
R	Power	24V supply

#### **Fossil Fuel Kit:**

- Prevents simultaneous operation
- Locks out heat pump
- Temperature-based switching
- Field-installed option

# **Changeover Controls**

Changeover determines when to switch between heat sources.

#### **Balance Point**

#### **Definition:**

- Outdoor temperature where heat pump capacity equals heat loss
- Typically 25-40°F
- Building specific
- Adjustable setting

## **Determining Balance Point:**

Balance Point = 65°F - (Heat Pump Capacity / Building Heat Loss Rate)

#### **Example:**

• Heat pump capacity at 30°F: 30,000 BTU/hr

- Building heat loss: 40,000 BTU/hr at 0°F
- Loss rate: 1,000 BTU/hr per degree
- Balance point = 65 (30,000/1,000) = 35°F

## **Temperature-Based Control**

#### **Outdoor Sensor Method:**

- Simple installation
- Fixed changeover point
- No utility rate consideration
- Common approach

## **Settings:**

• Changeover: 30-40°F typical

Differential: 2-5°F
Defrost lockout: 25°F
Emergency heat: Manual

#### **Economic Balance Point**

## **Cost-Based Switching:**

- Compares operating costs
- Requires rate inputs
- More complex setup
- Optimal savings

#### **Calculation:**

```
Economic Balance = Temperature where:
Heat Pump Cost/BTU = Gas Cost/BTU
```

#### **Factors:**

- Electric rate (\$/kWh)
- Gas rate (\$/therm)
- Heat pump COP
- Furnace efficiency

## **Efficiency Considerations**

Understanding efficiency metrics optimizes system selection and operation.

## **Heat Pump Efficiency**

## **HSPF** (Heating Seasonal Performance Factor):

- Seasonal heating efficiency
- BTUs per watt-hour
- Higher is better
- Range: 7.7-13+ HSPF

## **COP** (Coefficient of Performance):

- Instantaneous efficiency
- Varies with temperature
- Decreases as temperature drops
- 3.0 COP = 300% efficient

### **Temperature Impact:**

## **Outdoor Temp Typical COP Capacity**

47°F	3.5-4.0	100%
35°F	2.8-3.2	80%
25°F	2.2-2.6	60%
17°F	1.8-2.2	45%

## **System Optimization**

#### **Best Practices:**

- Size heat pump for cooling load
- Use furnace below balance point
- Optimize changeover temperature
- Regular maintenance both systems
- Monitor performance

## **Control Strategies:**

- Adaptive recovery
- Intelligent defrost
- Staged operation
- Load matching
- Utility demand response

# 13.7 Commissioning Heating Systems

Proper commissioning ensures systems operate safely and efficiently from day one.

## **Start-up Procedures**

Systematic start-up prevents problems and ensures proper operation.

#### **Pre-Start Checklist**

#### Mechanical:

- [] Gas piping complete and tested
- [] Venting properly installed
- [] Condensate drain connected
- [] Ductwork connected and sealed
- [] Filters installed
- [] Access panels secure

#### **Electrical:**

- [] Power supply verified
- [] Proper voltage confirmed
- [] Disconnect installed
- [] Control wiring complete
- [] Thermostat configured
- [] Grounding verified

## **Safety:**

- [] Gas leak test passed
- [] Venting clear
- [] Combustion air adequate
- [] Area clear of combustibles
- [] Carbon monoxide detector installed

## **Initial Start-up Sequence**

## 1. Power Application:

- Turn on disconnect
- o Check control voltage (24VAC)
- o Verify LED status
- Check error codes

#### 2. Gas Supply:

- o Open manual valve slowly
- o Purge air from line
- o Check inlet pressure
- Verify no leaks

#### 3. First Ignition:

o Set thermostat to call

- o Observe ignition sequence
- Verify flame establishment
- o Check for proper combustion

## 4. System Operation:

- Verify blower operation
- Check all safeties
- Monitor temperatures
- Listen for unusual noises

## **Temperature Rise Checks**

Proper temperature rise ensures efficient heat transfer and equipment longevity.

## **Measuring Temperature Rise**

#### **Procedure:**

- 1. Install thermometers in supply and return plenums
- 2. Operate furnace 10-15 minutes
- 3. Record temperatures simultaneously
- 4. Calculate difference
- 5. Compare to nameplate range

## **Acceptable Ranges:**

- Standard furnace: 30-60°F typical
- Condensing furnace: 35-65°F typical
- Check manufacturer nameplate
- Adjust blower speed if needed

## **Adjusting Temperature Rise:**

- Too high: Increase blower speed
- Too low: Decrease blower speed
- Check for restrictions
- Verify ductwork adequate

#### **Calculating Airflow**

## From Temperature Rise:

```
CFM = Output BTU/hr / (1.08 \times \Delta T)
```

#### **Example:**

• Output: 76,000 BTU/hr

- Temperature rise: 55°F
- $CFM = 76,000 / (1.08 \times 55) = 1,279 CFM$

# **Combustion Testing Requirements**

Combustion analysis ensures safe, efficient operation.

## **Required Tests**

#### **CSA B149.1 Requirements:**

- CO measurement (< 100 ppm air-free)
- Draft verification
- Gas pressure check
- Spillage test

## **Complete Analysis:**

<b>Parameter</b>	Acceptable Range	<b>Action if Outside</b>
CO	< 100 ppm air-free	Adjust combustion
$O_2$	5-9%	Adjust air/gas
$CO_2$	7-10% (natural gas)	Check burners
Stack Temp	300-500°F (non-condensing)	Check heat exchanger
Draft	-0.02" to -0.05" W.C.	Check venting

## **Adjustment Procedures**

## **Gas Pressure:**

- 1. Connect manometer to manifold tap
- 2. Operate furnace
- 3. Check against nameplate
- 4. Adjust if necessary
- 5. Typical: 3.5" W.C. natural gas

# **Combustion Adjustment:**

- 1. Clean burners if needed
- 2. Check orifice sizes
- 3. Verify primary air openings
- 4. Test and document
- 5. Re-test after adjustments

#### **Airflow Verification**

Proper airflow ensures comfort and equipment protection.

## **Static Pressure Testing**

#### **Measurement Points:**

- Supply plenum (positive)
- Return plenum (negative)
- Total external static
- Compare to blower curve

## **Acceptable Values:**

- Total external: < 0.5" W.C. typical
- Higher with accessories
- Check manufacturer specifications

#### **Airflow Measurement Methods**

## **Temperature Rise Method:**

- Simple calculation
- Described above
- Approximate value
- Good for verification

## **Velocity Traverse:**

- Pitot tube or anemometer
- Multiple readings
- Calculate average
- More accurate
- Time consuming

#### Flow Hood:

- Direct measurement
- Register by register
- Total all registers
- Most accurate
- Professional tool

#### **Control Verification**

Verify all controls operate properly.

## **Safety Control Testing**

#### **Limit Switch:**

- 1. Block return air partially
- 2. Monitor temperature rise
- 3. Verify shutdown before danger
- 4. Clear blockage
- 5. Verify auto restart

#### **Pressure Switch:**

- 1. Block vent partially
- 2. Verify shutdown
- 3. Check switch contacts
- 4. Clear blockage
- 5. Test restart

#### Flame Sensor:

- 1. Disconnect sensor wire
- 2. Call for heat
- 3. Verify shutdown timing
- 4. Reconnect sensor
- 5. Test normal operation

#### **Operating Control Testing**

#### **Thermostat:**

- Heating operation
- Cooling (if equipped)
- Fan operation
- Programming functions
- Temperature accuracy

## **Staging Controls:**

- First stage operation
- Second stage timing
- Outdoor sensor (if used)
- Proper sequencing

# **Documentation Requirements**

Proper documentation protects all parties and ensures traceability.

# **Start-up Report**

## **Required Information:**

- Date and technician
- Equipment model/serial
- Installation address
- Test results
- Adjustments made

#### **Test Data:**

<b>Parameter</b>	Re	ading	Acceptable	Pass/Fail
Gas pressure		"W.C.	3.2-3.8"	
Temperature rise		°F	35-65°	
CO level		ppm	<100	
Static pressure		"W.C.	<0.8"	
Amp draw		A	<fla< td=""><td></td></fla<>	

#### **Customer Documentation**

#### **Provide to Customer:**

- Operation manual
- Warranty information
- Maintenance requirements
- Emergency contacts
- Service records

### **Review with Customer:**

- Thermostat operation
- Filter maintenance
- Emergency shutdown
- Normal sounds
- Service schedule

# 13.8 Troubleshooting Heating Systems

Systematic troubleshooting efficiently identifies and resolves heating system problems.

## **No Heat Calls**

When the system doesn't respond to thermostat calls, systematic diagnosis finds the cause.

## **Diagnostic Sequence**

# **Step 1: Verify Power**

- Check disconnect/breaker
- Test transformer output (24VAC)
- Check fuse on control board
- Verify door switch closed
- Test voltage at furnace

## **Step 2: Check Thermostat**

- Verify settings correct
- Test batteries (if used)
- Jump R to W at furnace
- Check wire connections
- Test thermostat operation

# **Step 3: Safety Circuit**

- Check limit switches
- Test pressure switches
- Verify rollout switches
- Check door switch
- Test each component

#### **Step 4: Control Board**

- Check diagnostic LEDs
- Test control outputs
- Verify input signals
- Check for fault codes
- Test or replace board

#### **Common Causes and Solutions**

Problem	Symptoms	Solution
No power	Dead display, no response	Check breaker, disconnect
Bad transformer	No 24V	Replace transformer
Open limit	LED code, no ignition	Check airflow, reset
Thermostat issue	No call signal	Replace batteries, check wiring
Control board	Various codes	Diagnose and replace
Door switch	No response when closed	Adjust or tape temporarily

## **Inadequate Heat**

System runs but doesn't maintain temperature.

### **Causes and Diagnosis**

## **Undersized Equipment:**

- Heat loss calculation
- Check on design day
- Verify proper sizing
- Consider additions/changes

#### Low Gas Pressure:

- Measure manifold pressure
- Check with all appliances on
- Verify orifice size
- Adjust if needed

#### **Airflow Problems:**

- Dirty filter (most common)
- Closed registers
- Blocked returns
- Duct leakage
- Blower issues

## **Heat Exchanger Issues:**

- Cracked/failed exchanger
- Plugged exchanger
- Soot buildup
- Poor combustion

#### **Testing Procedures**

#### 1. Measure Temperature Rise:

- Should be within range
- Too high indicates low airflow
- o Too low indicates high airflow

## 2. Check Gas Input:

- Clock meter if possible
- o Calculate actual BTU
- Compare to nameplate

## 3. Verify Airflow:

- o Measure static pressure
- o Check all registers
- Inspect ductwork

# **Short Cycling**

Furnace starts and stops frequently without satisfying thermostat.

#### Causes

#### **Oversized Furnace:**

- Heats too quickly
- Poor comfort
- Reduced efficiency
- Equipment wear

#### **Thermostat Issues:**

- Poor location
- Anticipator setting
- Loose connection
- Defective thermostat

#### **Airflow Restrictions:**

- Dirty filter
- Closed registers
- Blocked return
- Undersized ducts

#### **Control Problems:**

- Limit switch tripping
- Pressure switch cycling
- Flame sensor marginal
- Control board issue

## **Diagnostic Steps**

## 1. Time the Cycles:

- o Note on/off times
- o Should run 5-15 minutes minimum
- Check against thermostat calls

## 2. Monitor Temperatures:

Watch temperature rise

- o Check limit operation
- Verify not overheating

#### 3. Check Thermostat:

- Verify location appropriate
- o Check anticipator (if mechanical)
- Test for loose connections

# **Noisy Operation**

Unusual noises indicate problems requiring attention.

## **Types of Noises**

## **Rumbling:**

- Dirty burners
- Improper combustion
- Delayed ignition
- Low gas pressure

## Whistling:

- Dirty filter
- Restricted airflow
- Undersized ducts
- Register issues

# **Banging/Popping:**

- Delayed ignition
- Duct expansion
- Dirty burners
- Backfire

## **Scraping/Squealing:**

- Blower bearing failure
- Belt issues (if used)
- Inducer motor problems
- Debris in blower

#### **Resolution Procedures**

## Noise Type Diagnostic Test Solution

Rumbling Visual burner inspection Clean burners

Noise Type	<b>Diagnostic Test</b>	Solution
Whistling	Static pressure test	Replace filter, check ducts
Banging	Observe ignition	Clean burners, check pressure
Scraping	Isolate source	Lubricate or replace component

# **Safety Lockouts**

System locks out requiring manual reset or power cycle.

# **Common Lockout Causes**

## **Ignition Failure:**

- No gas supply
- Bad ignitor
- Valve failure
- Control issue

#### Flame Failure:

- Dirty sensor
- Sensor position
- Grounding issue
- Weak flame

# **Limit Trip:**

- Overheating
- Airflow restriction
- Limit failure
- Heat exchanger issue

## **Pressure Switch:**

- Blocked vent
- Failed inducer
- Switch failure
- Tube problems

#### **Reset Procedures**

## 1. Identify Cause:

- Read fault codes
- o Check diagnostic LEDs
- o Test failed component

#### 2. Correct Problem:

- Fix root cause
- Don't just reset
- Test thoroughly

### 3. Reset System:

- o Power cycle if soft lockout
- Manual reset if required
- Clear fault history
- Test operation

# **Systematic Diagnostic Approach**

Professional troubleshooting follows logical sequences.

## **Troubleshooting Methodology**

## 1. Information Gathering:

- o Customer complaint
- System history
- Recent changes
- Symptoms observed

## 2. Visual Inspection:

- Overall condition
- Obvious problems
- Safety hazards
- Installation quality

## 3. Operational Test:

- o Run complete cycle
- Note sequence
- o Identify where fails
- Document findings

#### 4. Component Testing:

- Test suspect components
- Use proper procedures
- Verify with meters
- Replace if defective

#### 5. Verification:

- Test after repair
- o Run multiple cycles
- o Check all operations
- Document work

#### **Diagnostic Tools**

## **Essential Equipment:**

- Multimeter
- Manometer
- Combustion analyzer
- Temperature probes
- Amp clamp

## **Helpful Tools:**

- Diagnostic chart
- Wiring diagrams
- Sequence charts
- Manufacturer literature
- Smart phone apps

# **Chapter Review**

# **Summary**

This chapter covered comprehensive heating system knowledge:

#### **Forced Air Furnaces:**

- Component functions and types
- Efficiency ratings and technologies
- Multi-stage and modulating benefits
- Airflow principles critical
- Proper sizing essential

#### **Installation Requirements:**

- Location and clearance requirements
- Return air design critical
- Combustion air provisions
- Proper venting essential
- Electrical connections per code

## **Control Systems:**

- Thermostat types and operation
- Integrated furnace controls
- Safety and operating limits
- Communication protocols emerging
- Diagnostic capabilities valuable

## **Hydronic Systems:**

- Boiler types and materials
- Piping configurations important
- Component selection critical
- Temperature control strategies
- Code requirements specific

## **Radiant Heating:**

- In-floor provides comfort
- Various installation methods
- Control strategies affect efficiency
- Proper design essential

## **Dual Fuel Systems:**

- Heat pump integration beneficial
- Changeover control critical
- Economic optimization possible
- Efficiency considerations complex

## **Commissioning:**

- Systematic start-up required
- Testing validates installation
- Documentation protects all parties
- Customer education important

## **Troubleshooting:**

- Systematic approach essential
- Common problems predictable
- Proper tools required
- Safety always priority

## **System Design Exercises**

## **Exercise 1: Furnace Sizing**

#### Given:

Heat loss: 65,000 BTU/hr

Location: TorontoFuel: Natural gas

#### **Solution:**

- 1. Add safety factor:  $65,000 \times 1.25 = 81,250 \text{ BTU/hr}$
- 2. Select furnace: 80,000 BTU/hr input
- 3. At 95% efficiency: 76,000 BTU/hr output
- 4. Adequate capacity confirmed

#### **Exercise 2: Airflow Calculation**

#### Given:

• Furnace output: 60,000 BTU/hr

• Temperature rise: 45°F

#### **Calculate CFM:**

```
CFM = 60,000 / (1.08 \times 45) = 1,235 CFM
```

#### **Exercise 3: Hydronic Flow Rate**

#### Given:

• Zone heat loss: 30,000 BTU/hr

• Temperature drop: 20°F

### **Calculate GPM:**

```
GPM = 30,000 / (20 \times 500) = 3 GPM
```

# **Installation Planning**

#### **New Furnace Installation Checklist**

#### **Pre-Installation:**

- [] Load calculation completed
- [] Equipment selected
- [] Permits obtained
- [] Materials ordered
- [] Customer notified

## **Installation Day:**

- [] Old equipment removed
- [] New furnace positioned
- [] Gas piping connected

- [] Venting installed[] Electrical connected[] Condensate routed
- [] Ductwork modified

## **Commissioning:**

- [] Gas pressure set
- [] Temperature rise verified
- [] Combustion tested
- [] Static pressure checked
- [] Controls verified
- [] Documentation complete

# **Combustion Analysis Interpretation**

## **Sample Analysis Results**

## **Readings:**

• CO: 45 ppm air-free

O<sub>2</sub>: 7.5%
CO<sub>2</sub>: 8.2%
Stack: 385°F
Efficiency: 82%

## **Interpretation:**

- CO acceptable (< 100 ppm)
- Combustion good
- Efficiency appropriate for equipment
- No adjustment needed

# **Diagnostic Scenarios**

# **Scenario 1: No Heat - Morning Only**

## **Symptoms:**

- No heat first thing morning
- Works fine rest of day
- Condensing furnace
- Outdoor temperature below freezing

## **Diagnosis:**

- Condensate drain frozen
- Pressure switch open
- Overnight freezing

#### **Solution:**

- Reroute drain indoors
- Heat trace if necessary
- Insulate drain line

## **Scenario 2: Runs Constantly**

## **Symptoms:**

- Furnace never stops
- House stays cold
- High gas bills
- No error codes

## **Testing:**

- Temperature rise: 70°F (too high)
- Static pressure: 0.9" W.C. (high)
- Filter: Completely blocked

#### **Solution:**

- Replace filter
- Check all registers open
- Educate customer on maintenance

#### Scenario 3: Random Shutdowns

## **Symptoms:**

- Intermittent operation
- No pattern
- Various error codes
- Works after reset

## **Investigation:**

- Loose wire connection found
- Board connection corroded
- Vibration causing intermittent

#### **Solution:**

- Clean connections
- Apply dielectric grease
- Secure all wiring

## **Scenario 4: Loud Bang on Start**

## **Symptoms:**

- Loud bang on ignition
- Otherwise normal operation
- Getting worse over time
- Black marks visible

## **Diagnosis:**

- Delayed ignition
- Dirty burners
- Gas accumulation before ignition

#### **Solution:**

- Clean burners thoroughly
- Check gas pressure
- Verify ignitor position
- Test ignition timing

#### **Scenario 5: Poor Second Floor Heating**

#### **Symptoms:**

- First floor comfortable
- Second floor cold
- Single zone system
- Furnace cycles normally

## **Testing:**

- Airflow measurement shows imbalance
- Static pressure normal
- Temperature rise acceptable

#### **Solution:**

Balance dampers

- Partially close first floor registers
- Consider zoning system
- Check return air paths

# **Laboratory Exercises**

## Lab 1: Temperature Rise Measurement

## **Equipment:**

- Digital thermometers (2)
- Operating furnace
- Calculator

#### **Procedure:**

- 1. Install thermometers in supply and return
- 2. Run furnace 10 minutes
- 3. Record temperatures
- 4. Calculate rise
- 5. Compare to nameplate
- 6. Adjust blower if needed

# **Lab 2: Static Pressure Testing**

## **Equipment:**

- Manometer
- Drill and bits
- Test probes
- Tape

#### **Procedure:**

- 1. Drill test holes
- 2. Zero manometer
- 3. Measure supply static
- 4. Measure return static
- 5. Calculate total external
- 6. Compare to specifications
- 7. Document findings

# **Lab 3: Combustion Analysis**

## **Equipment:**

- Combustion analyzer
- Drill and bits
- Operating furnace

#### **Procedure:**

- 1. Warm up analyzer
- 2. Zero in fresh air
- 3. Insert probe in vent
- 4. Record all readings
- 5. Compare to standards
- 6. Make adjustments if needed
- 7. Retest after adjustments

## **Lab 4: Control Circuit Diagnosis**

### **Equipment:**

- Multimeter
- Wiring diagram
- Non-functioning furnace

#### **Procedure:**

- 1. Check power supply
- 2. Test transformer output
- 3. Verify thermostat signal
- 4. Check safety switches
- 5. Test control board outputs
- 6. Identify failed component
- 7. Document diagnosis

# **Key Terms**

**AFUE:** Annual Fuel Utilization Efficiency - seasonal efficiency rating including cycling losses.

**Air Handler:** Blower section that moves air through ductwork system.

**Aquastat:** Temperature control device for hydronic boilers maintaining water temperature.

Balance Point: Outdoor temperature where heat pump capacity equals building heat loss.

**CFM:** Cubic Feet per Minute - measurement of airflow volume.

**Circulator:** Pump that moves water through hydronic system.

**Combustion Analysis:** Testing of flue gases to verify proper burning.

**Condensing Furnace:** High-efficiency furnace that extracts latent heat from flue gases.

**Delta T** ( $\Delta$ **T**): Temperature difference between supply and return air or water.

**ECM Motor:** Electronically Commutated Motor providing variable speed operation.

**Expansion Tank:** Vessel accommodating water expansion in hydronic systems.

Flame Sensor: Device detecting presence of flame using rectification or thermocouples.

**Heat Exchanger:** Component separating combustion products from heated air or water.

**HSPF:** Heating Seasonal Performance Factor measuring heat pump efficiency.

Hydronic: Heating system using hot water as distribution medium.

**IFC:** Integrated Furnace Control managing all furnace operations.

**Inducer:** Fan creating draft through heat exchanger and venting system.

**Limit Switch:** Safety device preventing overheating by shutting off gas.

Manifold: Distribution header for multiple zones or burners.

**Modulating:** Variable capacity operation matching output to load.

**MERV:** Minimum Efficiency Reporting Value for air filter effectiveness.

**Orifice:** Precision opening metering gas flow to burners.

**PSC Motor:** Permanent Split Capacitor motor, standard blower type.

**Radiant Heat:** Heating through infrared radiation rather than air movement.

Return Air: Air drawn back to furnace for reheating.

Static Pressure: Resistance to airflow in duct system, measured in inches W.C.

**Temperature Rise:** Difference between supply and return air temperatures.

**Thermocouple:** Safety device generating millivolts from flame heat.

**Two-Stage:** Furnace operating at two capacity levels for better comfort.

**Zone:** Separately controlled area in heating system.

# **End of Chapter 13**

This comprehensive chapter on Heating Systems provides the essential knowledge for installing, commissioning, and servicing modern heating equipment. Understanding these systems ensures safe, efficient, and comfortable heating for Canadian homes and businesses.

Students should be able to size and select appropriate equipment, perform proper installation following codes and manufacturer requirements, commission systems correctly, and troubleshoot problems systematically. Regular maintenance and proper operation of these systems ensures long life and optimal performance.

The integration of different heating technologies, from traditional furnaces to modern heat pumps and radiant systems, offers flexibility in meeting diverse comfort needs while maximizing efficiency. As technology continues to advance, the fundamental principles covered in this chapter remain the foundation for working with heating systems.