CHAPTER 16: Water Heaters

Learning Objectives

Upon completion of this chapter, you will be able to:

- 1. **Identify** different types of water heaters and their applications
- 2. **Understand** the components and operation of various water heater systems
- 3. Install water heaters according to CSA B149.1 and manufacturer specifications
- 4. Calculate proper water heater sizing based on demand and usage patterns
- 5. Configure tankless water heaters for optimal performance
- 6. Install and test temperature and pressure relief valves properly
- 7. **Perform** routine maintenance on water heating systems
- 8. **Troubleshoot** common water heater problems systematically
- 9. Apply code requirements for safe water heater installation
- 10. Educate customers on water heater operation and maintenance

Introduction

Water heating represents the second-largest energy use in most homes, accounting for 15-25% of total energy consumption. Gas water heaters provide reliable, cost-effective hot water for residential, commercial, and industrial applications. Understanding their design, installation, and maintenance is essential for gas technicians.

This chapter covers the full spectrum of gas water heating technology, from traditional atmospheric tank heaters to modern condensing tankless units. We'll explore:

- Various water heater types and their applications
- Critical components and their functions
- Code-compliant installation procedures
- Proper sizing methodologies
- Maintenance requirements
- Systematic troubleshooting approaches

Water heater technology continues evolving with efficiency improvements, smart controls, and hybrid designs. However, fundamental principles of safe gas combustion, proper venting, and temperature/pressure safety remain constant.

16.1 Water Heater Types

Atmospheric Storage Tank

Operating Principle: Atmospheric water heaters use natural draft for venting, relying on the buoyancy of hot combustion gases to create draft through the vent system.

Construction Features:

- Glass-lined steel tank (30-80 gallons residential)
- Central flue tube through tank
- Natural draft hood
- Standing pilot or electronic ignition
- Bottom-fired burner
- Efficiency: 60-80% AFUE

Components:

1. Tank Assembly

- Welded steel construction
- o Glass lining (porcelain enamel)
- o Foam insulation (R-8 to R-16)
- Outer jacket

2. Combustion System

- Atmospheric burner
- o Pilot assembly (thermocouple)
- Main burner orifice
- Burner chamber

3. Venting System

- o Draft hood
- o B-vent connector
- o Natural draft operation

Advantages:

- Lower initial cost
- Simple operation
- No electricity required (pilot models)
- Reliable and proven technology
- Easy to service

Disadvantages:

- Lower efficiency
- Requires vertical venting
- Susceptible to backdrafting
- Higher standby losses
- Limited installation locations

Typical Specifications:

Capacity: 30, 40, 50, 60, 75 gallons

Input: 30,000-75,000 BTU/h
Recovery: 30-41 gallons/hour
First Hour Rating: 60-90 gallons

Efficiency: 60-62% (standard), 76-80% (ENERGY STAR)

Power Vent Storage Tank

Operating Principle: Power vent water heaters use an electric blower to exhaust combustion products, allowing horizontal venting and longer vent runs.

Construction Features:

- Similar tank construction to atmospheric
- Blower assembly on top
- Pressure switch safety
- Horizontal venting capability
- Electronic ignition typical
- Efficiency: 62-82% AFUE

Venting System:

1. Blower Assembly

- o Centrifugal fan
- o 30-150 CFM typical
- Pre-purge and post-purge
- Sealed combustion chamber

2. Vent Materials

- o PVC/CPVC approved
- o ABS in some applications
- Maximum temperatures considered

Control Sequence:

- 1. Thermostat calls for heat
- 2. Blower starts (pre-purge)
- 3. Pressure switch proves
- 4. Ignition sequence begins
- 5. Main burner fires
- 6. Continuous operation
- 7. Thermostat satisfied
- 8. Gas valve closes
- 9. Post-purge (30-60 seconds)
- 10. Blower stops

Advantages:

- Flexible venting options
- Longer vent runs possible

- Reduced backdraft risk
- Can vent through sidewall
- Better for tight homes

Disadvantages:

- Requires electricity
- More complex controls
- Blower noise
- Higher initial cost
- No operation during power outage

Direct Vent Storage Tank

Operating Principle: Direct vent water heaters draw combustion air from outside through a sealed system, eliminating indoor air consumption.

Construction Features:

- Sealed combustion chamber
- Concentric or dual-pipe venting
- No indoor air required
- Power vented or natural draft
- Higher efficiency potential

Venting Configurations:

Concentric Venting:

- Pipe within pipe design
- Exhaust in center
- Intake in outer annulus
- Single wall penetration
- Preheats combustion air

Dual-Pipe System:

- Separate intake and exhaust
- More flexible routing
- Two wall penetrations
- Various termination options

Installation Benefits:

- No impact on indoor air quality
- Ideal for tight construction

- Reduced clearances possible
- Consistent combustion air temperature
- Zone 3 (bedroom) installation allowed

Typical Applications:

- Mobile homes
- Tight/efficient homes
- Confined space installations
- Cold climate applications
- Where indoor air quality critical

Tankless (Instantaneous)

Operating Principle: Tankless water heaters heat water on-demand as it flows through the unit, eliminating standby losses.

Types:

Non-Condensing Tankless:

- Efficiency: 80-85%
- Stainless steel heat exchanger
- Higher exhaust temperatures
- Category III venting

Condensing Tankless:

- Efficiency: 90-98%
- Secondary heat exchanger
- Recovers latent heat
- PVC venting possible
- Condensate management required

Key Components:

1. Heat Exchanger

- Copper or stainless steel
- Finned tube design
- High surface area
- Corrosion resistant

2. Modulating System

- o Variable gas valve
- Modulating burner
- o 5:1 to 15:1 turndown
- o Precise temperature control

3. Flow Sensors

- o Turbine or paddle wheel
- o 0.5-0.75 GPM activation
- Digital flow measurement
- Leak detection capability

4. Control Board

- Microprocessor controlled
- Multiple safety circuits
- Diagnostic capabilities
- o Remote control options

Performance Specifications:

```
Flow Rate: 3-11 GPM
Input: 120,000-199,900 BTU/h
Temperature Rise:
- 35°F at 7 GPM
- 45°F at 5 GPM
- 70°F at 3 GPM
Minimum Flow: 0.5 GPM
```

Maximum Pressure: 150 PSI

Advantages:

- Endless hot water
- Space saving
- No standby losses
- Longer equipment life (20+ years)
- Precise temperature control

Disadvantages:

- Higher initial cost
- Complex installation
- Minimum flow requirements
- Cold water sandwich effect
- · Higher gas demand

Condensing Storage

Operating Principle: Condensing storage water heaters achieve high efficiency by extracting latent heat from combustion gases, similar to condensing furnaces.

Design Features:

- 90-98% thermal efficiency
- Secondary heat exchanger
- PVC venting capability

- Modulating burner (some models)
- Advanced controls

Construction:

1. Primary Heat Exchanger

- Submerged in tank
- Spiral or helical design
- o Maximum surface area

2. Secondary Heat Exchanger

- Captures latent heat
- Condensate production
- Corrosion-resistant materials

3. Condensate Management

- Collection tray
- Neutralization (if required)
- o Proper drainage

Efficiency Features:

- Low stack temperatures (100-140°F)
- Reduced cycling losses
- Better stratification
- Smart controls
- Heat pump hybrid options

Applications:

- High-use residential
- Light commercial
- Energy-conscious installations
- Where gas savings justify cost

Commercial Water Heaters

Types and Features:

Power Burner Storage:

- 75-100 gallon capacity
- 75,000-500,000 BTU/h input
- Forced combustion air
- Higher recovery rates
- Modulating options available

Copper-Fin Tube Heaters:

- Fast recovery
- 100-500,000 BTU/h
- Multiple pass design
- 80-88% efficiency
- Compact footprint

Condensing Commercial:

- 95-98% efficiency
- 100,000-2,000,000 BTU/h
- Stainless steel construction
- Modulating operation
- Advanced controls

Installation Requirements:

- Dedicated combustion air
- Larger gas connections (1"-2")
- Multiple unit manifolds
- Building automation interface
- Seismic bracing (zones)

Control Features:

- Lead-lag operation
- Outdoor reset capability
- Building management interface
- Remote monitoring
- Predictive maintenance

Indirect Water Heaters

Operating Principle: Indirect water heaters use boiler water to heat domestic water through a heat exchanger, eliminating direct flame contact.

Types:

Tank-in-Tank Design:

- Inner domestic water tank
- Outer boiler water jacket
- Large heat transfer area
- Natural convection

Internal Coil Design:

- Coiled heat exchanger
- Immersed in domestic water
- Forced circulation typical
- Compact design

External Heat Exchanger:

- Plate or shell-tube
- Separate from storage tank
- High heat transfer rates
- Complex piping

System Components:

- 1. Storage tank (30-119 gallons)
- 2. Heat exchanger
- 3. Circulator pump
- 4. Aquastat control
- 5. Check valve
- 6. Mixing valve (optional)

Control Strategy:

Priority Control:

- 1. DHW call from aquastat
- 2. Boiler fires to high limit
- 3. Circulator runs
- 4. Zone valves close (priority)
- 5. Heat transfer to tank
- 6. Tank satisfied
- 7. Return to space heating

Advantages:

- High recovery rates
- Long tank life (no flame)
- Reduced maintenance
- Combined system efficiency
- No separate venting

Disadvantages:

- Requires boiler operation
- Summer boiler cycling
- Complex controls
- Higher initial cost
- Space requirements

16.2 Water Heater Components

Tank Construction

Materials and Design:

Steel Tank:

- Carbon steel construction
- 0.25-0.375" thickness
- Welded seams
- Pressure tested to 300 PSI
- Working pressure: 150 PSI

Glass Lining:

- Porcelain enamel coating
- Applied at 1500°F
- Multiple coats
- Prevents corrosion
- Thermal shock resistant

Insulation:

- Polyurethane foam
- R-8 to R-24 values
- 2-3" thickness typical
- CFC-free formulation
- Reduces standby losses

Outer Jacket:

- Baked enamel finish
- Corrosion protection
- Aesthetic appearance
- Access panels

Tank Connections:

```
Standard Residential Tank:
- Cold inlet: 3/4" NPT (top)
- Hot outlet: 3/4" NPT (top)
- Drain valve: 3/4" garden hose
- T&P valve: 3/4" NPT
- Gas connection: 1/2" NPT
```

Anode Rods

Purpose: Sacrificial anode rods protect the tank from corrosion through galvanic action.

Types:

Magnesium Anode:

- Most common
- Standard protection
- 3-5 year life typical
- Best for soft water

Aluminum Anode:

- Lighter weight
- Reduces odor issues
- Longer life
- Better for hard water

Zinc/Aluminum Alloy:

- Reduces sulfur odors
- Antibacterial properties
- Premium option
- 5-7 year life

Powered Anode:

- Impressed current system
- Non-sacrificial
- Permanent installation
- Requires power supply

Inspection and Replacement:

Inspection Frequency:

- Year 1: Initial check
- Years 2-5: Annual inspection
- Years 5+: Every 6 months

Replacement Indicators:

- 75% consumed
- Heavy calcium deposits
- Exposed steel core wire
- Tank age over 5 years

Installation Tips:

- 1. Use Teflon tape on threads
- 2. Don't overtighten
- 3. May need to bend for clearance
- 4. Check headroom before removal
- 5. Consider flexible anode

Dip Tubes

Function: Delivers cold water to tank bottom, promoting stratification and preventing mixing.

Construction:

- Polypropylene typical
- Heat-resistant plastic
- 3/4" diameter
- Anti-siphon hole at top

Types:

Standard Dip Tube:

- Straight pipe
- 6" from tank bottom
- Basic design

Curved Dip Tube:

- Creates swirl action
- Self-cleaning effect
- Reduces sediment

Diffuser Dip Tube:

- Perforated bottom
- Spreads incoming water
- Reduces turbulence

Common Problems:

- Deterioration (1993-1997 issue)
- Breakage from thermal shock
- Sediment blockage
- Incorrect length

Replacement Procedure:

- 1. Turn off water and gas
- 2. Drain several gallons
- 3. Remove cold inlet nipple
- 4. Extract old dip tube
- 5. Insert new tube
- 6. Verify proper length
- 7. Reinstall nipple

Temperature and Pressure Relief Valves

Purpose: Safety device preventing tank rupture from excess temperature or pressure.

Operating Parameters:

• Pressure relief: 150 PSI

• Temperature relief: 210°F

• Combined T&P most common

Construction:

- Bronze body typical
- Stainless steel spring
- Thermostat probe
- Test lever
- Discharge connection

Operation:

- 1. Pressure Relief:
 - Spring-loaded disc
 - o Opens at 150 PSI
 - Full flow capacity
- 2. Temperature Relief:
 - o Thermal element
 - o Expands at 210°F
 - o Opens valve mechanically

^{*}Detailed coverage in Section 16.6

Gas Control Valves

Types:

Mechanical (Millivolt):

- Thermocouple powered
- No external power needed
- Simple operation
- Standing pilot

Electronic (Thermopile):

- Self-powered
- Electronic ignition
- Status indicators
- Diagnostic capability

Components:

1. Main Valve

- o Redundant solenoids
- Slow-opening design
- Safety shutoff

2. Pilot Valve

- o Thermocouple operated
- Safety function
- Manual control

3. Thermostat

- Immersion sensing
- o Adjustable 90-160°F
- o Differential 10-15°F

4. Regulator

- Maintains outlet pressure
- o Compensates for inlet variation
- o 3.5" W.C. typical

Control Settings:

Typical Residential Settings:

- Pilot: Continuous or intermittent
- Temperature: 120°F recommended
- Vacation: Pilot only
- Off: Complete shutdown

Thermostats

Mechanical Thermostats:

Rod and Tube Type:

- Copper tube sensing
- Invar rod inside
- Differential expansion
- Operates gas valve

Bi-Metal Type:

- Two metals bonded
- Bends with temperature
- Snap-action contacts
- Simple and reliable

Electronic Thermostats:

Thermistor Sensing:

- 10K ohm typical
- Precise measurement
- Digital control
- ±1°F accuracy

Microprocessor Control:

- Multiple sensors
- Learning algorithms
- Diagnostic features
- Communication capability

Smart Features:

- WiFi connectivity
- Usage tracking
- Leak detection
- Vacation modes
- Energy monitoring

Burner Assemblies

Atmospheric Burner:

Components:

- Cast iron or steel
- Multiple ports
- Venturi mixing
- Primary air adjustment

Operation:

- 1. Gas flows through orifice
- 2. Venturi creates vacuum
- 3. Primary air entrained
- 4. Mixture burns at ports
- 5. Secondary air from room

Power Burner:

Components:

- Forced draft blower
- Premix design
- Stainless steel mesh
- Modulation capability

Advantages:

- Complete combustion
- Higher efficiency
- Quieter operation
- Lower emissions

Venting Components

Draft Hoods (Atmospheric):

- Prevents backdraft
- Dilution air inlet
- Built-in or separate
- Must remain unobstructed

Power Vent Components:

- Blower assembly
- Pressure switch
- Vent connector
- Termination fitting

Direct Vent Components:

- Concentric termination
- Intake/exhaust pipes
- Wall thimble
- Termination kit

16.3 Water Heater Installation

Location Requirements per Code

CSA B149.1 Requirements:

General Location Rules:

- 1. Accessibility
 - o Minimum 24" front clearance
 - Service access required
 - o Removal path planned
- 2. Floor Protection
 - Non-combustible base (concrete)
 - o Or listed protective material
 - o Garage: 18" elevation required

3. Prohibited Locations

- Bedrooms (except direct vent)
- o Bathrooms (except direct vent)
- Clothes closets
- o Under stairs (restricted)

Zone Classifications:

Zone 1 - General Space:

- Living rooms
- Kitchens
- Hallways
- Open basements

Zone 2 - Restricted:

- Storage rooms
- Furnace rooms
- Garages (with elevation)

Zone 3 - Special Requirements:

- Bedrooms (direct vent only)
- Bathrooms (direct vent only)
- Must have sealed combustion

Seismic Requirements:

- Zones 4 and higher
- Two straps required
- Upper: 1/3 from top
- Lower: 1/3 from bottom
- Lag bolts to studs

Clearances to Combustibles

Atmospheric Water Heaters:

```
Standard Clearances:
- Sides: 1" minimum
- Back: 1" minimum
- Front: 6" service clearance
- Top: 12" to combustibles
- Draft hood: 6" all directions
- Vent connector: 6" (B-vent)
```

Power Vent Units:

```
Typical Clearances:
- Sides: 2" minimum
- Back: 0" (some models)
- Front: 4" minimum
- Top: 12" to ceiling
- Vent: Per manufacturer
```

Direct Vent Units:

```
Reduced Clearances:
- Sides: 0" (some models)
- Back: 0" (some models)
- Front: 4" service
- Vent: Per certification
```

Clearance Reduction:

- Use approved shields
- Maintain 1" air gap
- Sheet metal acceptable
- Follow tables in code

Combustion Air Provisions

Natural Draft Requirements:

Two-Opening Method:

```
Upper Opening (within 12" of ceiling):
- 1 sq.in. per 4,000 BTU/h

Lower Opening (within 12" of floor):
- 1 sq.in. per 4,000 BTU/h

Example: 40,000 BTU/h heater
Upper: 40,000 ÷ 4,000 = 10 sq.in.
Lower: 40,000 ÷ 4,000 = 10 sq.in.
```

Single-Opening Method:

```
Opening Size:
- 1 sq.in. per 3,000 BTU/h
- Within 12" of ceiling

Example: 40,000 BTU/h
40,000 ÷ 3,000 = 13.3 sq.in.
```

Mechanical Ventilation:

- Engineered system
- Interlocked with appliance
- Proven before operation
- Calculation required

Gas Piping Connections

Sizing Requirements:

Typical Connections:

```
Water Heater Size | Inlet Size 30-40 gallon | 1/2" NPT 50-75 gallon | 1/2" NPT Tankless <199k | 3/4" NPT Tankless >199k | 1" NPT Commercial | 1"-2" NPT
```

Installation Requirements:

1. Shutoff Valve

- o Within 6 feet
- Accessible location
- Approved type
- 2. Union

- o Downstream of valve
- o Allows removal
- o Ground joint type

3. Drip Leg

- o 3" minimum length
- o Before controls
- Capped nipple

4. Flexible Connector

- Listed for gas
- o 36" maximum length
- No concealed locations

Pressure Requirements:

Supply Pressure: Minimum: 5" W.C.

Maximum: 10.5" W.C. (NG) Maximum: 13" W.C. (LP)

Venting Requirements per Category

Category I (Atmospheric):

- B-vent required
- Vertical termination
- Natural draft
- Minimum height: 5 feet

Category II (Not common):

- Condensing with positive pressure
- Special materials required

Category III (Power Vent):

- Non-condensing positive pressure
- Stainless steel or approved plastic
- Horizontal venting allowed

Category IV (Condensing):

- Positive pressure condensing
- PVC/CPVC approved
- Slope for drainage
- Condensate management

Common Venting:

Connector Rules:

- Rise: 1/4" per foot minimumLength: Not >75% of heightSize: Not smaller than outlet
- Support: Every 4 feet

Temperature and Pressure Relief Valve Discharge

Discharge Piping Requirements:

Material:

- Copper
- CPVC (rated for temperature)
- Galvanized steel
- PEX (if rated)

Installation:

Requirements:

- 3/4" minimum diameter
- No reducers
- No threads on outlet
- Maximum 6" above floor
- Visible termination
- No caps or plugs
- Slope to drain
- Support required

Prohibited:

- Direct connection to drain
- Discharge outdoors (freeze risk)
- Threading of discharge end
- Concealed termination

Earthquake Strapping

Requirements by Zone:

Seismic Zone 4+:

- Two straps mandatory
- 22-gauge minimum
- 1-1/2" wide minimum
- Lag bolts to studs

Installation:

Upper Strap:

- Within upper 1/3 of tank
- 360° wrap or two 180° straps
- Secured to wall studs

Lower Strap:

- Within lower 1/3 of tank
- Above controls
- Same requirements as upper

Additional Bracing:

- Rigid gas piping
- Flexible connector limits
- Platform mounting
- Wall brackets available

Drain Pan Requirements

When Required:

- Above living space
- Where damage possible
- Finished spaces
- Local code requirements

Pan Specifications:

- 2" larger than heater diameter
- 1-1/2" to 2-1/2" depth
- Corrosion-resistant material
- 3/4" drain connection

Drain Piping:

- To approved location
- Visible termination
- Indirect waste preferred
- Same as T&P discharge

16.4 Water Heater Sizing

First Hour Rating (FHR)

Definition: Amount of hot water delivered in first hour of use, starting with full tank of hot water.

Calculation:

```
FHR = Tank Capacity + (Recovery Rate \times 0.7)

Example:

50-gallon tank

40 GPH recovery

FHR = 50 + (40 \times 0.7) = 78 gallons
```

Factors Affecting FHR:

- Tank size
- Input BTU/h
- Temperature rise
- Draw pattern
- Thermostat setting

Using FHR for Sizing:

- 1. Determine peak hour demand
- 2. Select heater with FHR \geq demand
- 3. Consider 10-20% safety factor

Recovery Rate

Definition: Gallons per hour raised by specific temperature rise (usually 90°F or 100°F).

Calculation Formula:

```
Recovery (GPH) = (BTU/h × Efficiency) ÷ (8.33 × ΔT)

Where:
8.33 = pounds per gallon of water
ΔT = temperature rise (°F)

Example:
40,000 BTU/h input
80% efficiency
90°F rise

Recovery = (40,000 × 0.80) ÷ (8.33 × 90)
Recovery = 32,000 ÷ 750
Recovery = 42.7 GPH
```

Standard Recovery Rates:

```
Input (BTU/h) | Recovery (GPH @ 90°F)
```

30,000	32
36,000	38
40,000	43
50,000	53
75,000	80

Storage Capacity

Residential Sizes:

30 gallons: 1-2 people
40 gallons: 2-3 people
50 gallons: 3-4 people
60-75 gallons: 4+ people
80+ gallons: Large families

Usable Capacity: Typically 70% of tank volume due to:

- Stratification
- Mixing during draw
- Temperature differential

Storage vs. Recovery Trade-off:

- Larger tank = longer initial supply
- Higher recovery = faster reheat
- Balance based on usage pattern

Calculating Hot Water Demand

Residential Demand Estimation:

Peak Hour Demand Method:

```
Activity | Gallons Used Shower | 10-15 Bath | 15-20 Shaving | 2 Hands/face wash | 4 Shampoo | 4 Dishwasher | 6-10 Clothes washer | 25-40 Food prep | 5 Hand dishwashing | 4
```

Example Family of 4:

```
Morning Peak Hour:
    3 showers × 12 gal = 36 gal
```

```
- 1 shaving × 2 gal = 2 gal
- 4 face wash × 2 gal = 8 gal
- Food prep = 5 gal
Total = 51 gallons

Select: 50-gal tank with 40+ GPH recovery
Or: 40-gal tank with 50+ GPH recovery
```

Diversity Factors:

- Not all fixtures used simultaneously
- Apply 0.6-0.8 factor for large homes
- Consider lifestyle patterns

Tankless Flow Rate Requirements

Flow Rate Determination:

Fixture Flow Rates:

```
Fixture | GPM @ 40 PSI Shower | 2.0-2.5 Kitchen sink | 1.5-2.0 Bathroom sink | 0.5-1.0 Bathtub | 4.0-5.0 Washing machine | 2.0-3.0 Dishwasher | 1.0-1.5
```

Simultaneous Use Calculation:

```
Example Home:
- 2 showers: 2.5 × 2 = 5.0 GPM
- 1 kitchen sink: 1.5 GPM
Total required: 6.5 GPM

With 70°F rise:
Select unit rated ≥7 GPM @ 70°F
```

Sizing by Temperature Rise:

```
Required GPM = BTU/h \div (500 \times \DeltaT)

Example:

150,000 BTU/h unit

70°F temperature rise

GPM = 150,000 \div (500 \times 70)

GPM = 150,000 \div 35,000

GPM = 4.3 GPM
```

Temperature Rise Considerations

Determining Temperature Rise:

```
ΔT = Desired Temp - Inlet Temp
Winter Conditions:
Desired: 120°F
Inlet: 40°F (cold climates)
Rise: 80°F

Summer Conditions:
Desired: 120°F
Inlet: 70°F (warm climates)
Rise: 50°F
```

Regional Inlet Temperatures:

```
Region | Winter Inlet
Northern Canada | 35-40°F
Southern Canada | 40-50°F
Northern US | 40-45°F
Central US | 45-55°F
Southern US | 55-70°F
```

Impact on Sizing:

Storage Tank:

- Higher rise = lower recovery
- Size tank larger for cold climates
- Or increase BTU input

Tankless:

- Higher rise = lower flow rate
- Critical for proper sizing
- May need multiple units

Commercial Applications:

```
Restaurant Dishwasher:
- Required: 180°F
- Inlet: 50°F
- Rise: 130°F
- High BTU input needed
- Consider booster heater
```

16.5 Tankless Water Heater Installation

Location Considerations

Indoor Installation:

Preferred Locations:

- Utility room
- Basement
- Garage (freeze-protected)
- Mechanical closet
- Attic (if accessible)

Space Requirements:

```
Minimum Clearances:
- Front: 24" service access
- Sides: 4" typical
- Back: 0-1" (wall-mount)
- Top: 12" minimum
- Bottom: 12" minimum
```

Mounting Considerations:

- Wall strength (50-80 lbs)
- Vibration isolation
- Service accessibility
- Venting routes
- Condensate drainage

Outdoor Installation:

Advantages:

- No indoor space required
- No venting needed
- No combustion air provisions
- Easier installation

Requirements:

- Freeze protection zones
- Weather-resistant enclosure
- Wind protection
- Electrical connection (GFCI)
- Service clearances

Venting (Concentric vs. Separate)

Concentric Venting:

Design:

- Exhaust pipe inside intake pipe
- Single penetration
- Combustion air preheated
- Compact termination

Installation:

```
Typical Specifications:
- 3"/5" or 4"/6" diameters
- Maximum length: 65-150 feet
- Deduct for elbows:
- 90° elbow = 5 feet
- 45° elbow = 2.5 feet
```

Advantages:

- Single wall penetration
- Cleaner appearance
- Preheated combustion air
- Simplified installation

Separate Venting:

Twin Pipe System:

- Independent intake/exhaust
- Greater flexibility
- Longer runs possible
- Multiple termination options

Installation Requirements:

```
Pipe Specifications:
- 2", 3", or 4" diameter
- PVC/CPVC (condensing)
- Stainless (non-condensing)
- Support every 5 feet
```

Termination Requirements:

```
Clearances from Termination:
- Grade: 12" minimum
- Window: 4 feet
- Door: 4 feet
- Inside corner: 3 feet
- Gas meter: 3 feet
- Forced air inlet: 10 feet
```

Gas Line Sizing

High Input Requirements:

Tankless heaters require substantial gas flow:

```
Unit Size | BTU/h Input | CFH Required

Small | 120,000 | 120

Medium | 150,000 | 150

Large | 199,900 | 200

Commercial | 380,000 | 380
```

Pipe Sizing Example:

```
200,000 BTU/h unit
50 feet from meter
2 PSI system
```

Required: 1" minimum

Recommended: 1-1/4" for future

Pressure Considerations:

Minimum: 5" W.C. operatingMaximum: 10.5" W.C. static

• Measure at full flow

• Size for maximum demand

Manifold Systems:

• 2 PSI systems common

• Regulators at equipment

• Smaller pipe sizes

Professional design required

Water Flow Requirements

Minimum Flow Rate:

• Activation: 0.5-0.75 GPM

Continuous: 0.5 GPM minimumMaximum: 8-11 GPM typical

Pressure Requirements:

• Minimum: 30 PSI

• Recommended: 40-60 PSI

• Maximum: 150 PSI

• PRV if >80 PSI

Flow Sensors:

- Turbine type common
- Hall effect sensing
- Digital measurement
- Self-cleaning designs

Low-Flow Issues:

- Unit won't activate
- Temperature fluctuation
- Cycling on/off
- Cold water sandwich

Freeze Protection

Built-in Protection:

Electric Heaters:

- Activate at 35-40°F
- 100-200 watts typical
- Protects heat exchanger
- Requires constant power

Recirculation Mode:

- Pump activation
- Circulates water
- Prevents freezing
- Battery backup recommended

Installation Protection:

Pipe Insulation:

- All exposed piping
- R-3 minimum
- Vapor barrier exterior
- Heat tape if necessary

Drain-Down Provisions:

• Isolation valves

- Drain valves
- Service valves
- Freeze protection solenoid

Cold Climate Considerations:

Additional Measures:

- Indoor installation preferred
- Insulated enclosures
- Wind screens
- Pipe routing inside
- Backup freeze protection

Filtration Requirements

Inlet Strainer:

- 200-400 mesh typical
- Prevents debris entry
- Cleanable design
- Pressure drop consideration

Scale Prevention:

Water Softener:

- Recommended >7 grains hardness
- Protects heat exchanger
- Extends equipment life
- Reduces maintenance

Scale Inhibitors:

- Phosphate injection
- Electronic treatment
- Template-assisted crystallization
- Various effectiveness

Maintenance Access:

- Install unions
- Service valves
- Flush ports
- Filter location accessible

Condensate Drainage

Condensate Production:

Approximate Rates:

- 1 gallon per 100,000 BTU/h
- pH 3-4 (acidic)
- Continuous during operation

Drainage Requirements:

Piping:

- 3/4" minimum
- Corrosion-resistant
- Slope 1/4" per foot
- Trap required

Neutralization:

- Required by some codes
- pH > 5 for disposal
- Neutralizer kit available
- Annual media replacement

Disposal Options:

- 1. Floor drain (with trap primer)
- 2. Laundry tub
- 3. Condensate pump
- 4. Exterior (freeze-protected)

Common Problems:

- Frozen condensate lines
- Blocked drains
- Corrosion damage
- Trap dry-out

16.6 Temperature and Pressure Relief Valves

Purpose and Operation

Safety Function: T&P relief valves prevent catastrophic tank failure by releasing water when temperature or pressure exceeds safe limits.

Dual Protection:

Pressure Relief:

- Opens at 150 PSI
- Prevents tank rupture
- Spring-loaded mechanism
- Full flow capacity

Temperature Relief:

- Opens at 210°F
- Prevents steam explosion
- Thermal probe sensing
- 3" immersion typical

Operating Principle:

Normal Conditions:

- Valve remains closed
- Spring pressure maintains seal
- No leakage

Over-Pressure:

Sequence:

- 1. Pressure exceeds 150 PSI
- 2. Overcomes spring force
- 3. Valve opens
- 4. Water discharged
- 5. Pressure reduced
- 6. Valve closes

Over-Temperature:

Sequence:

- 1. Temperature exceeds 210°F
- 2. Thermal element expands
- 3. Mechanically opens valve
- 4. Steam/water discharged
- 5. Temperature reduced
- 6. Valve resets

Sizing Requirements

Capacity Rating: BTU/hr relief capacity must equal or exceed heater input.

Standard Ratings:

Sizing Formula:

```
Required GPM = BTU/h \div 50,000

Example:

200,000 BTU/h heater

200,000 \div 50,000 = 4 GPM minimum
```

Connection Size:

• Residential: 3/4" NPT typical

• Commercial: 3/4" to 2"

- Must match tank tapping
- No reducers allowed

Installation Position

Approved Locations:

Top Installation:

- Most common
- Dedicated tapping
- Within 6" of tank top
- No intervening valves

Side Installation:

- Upper 6" of tank
- Hot water space
- Probe fully immersed
- Proper orientation

Requirements:

1. **Direct Connection**

- No restrictions
- o Full-size opening
- No reducers

2. Accessibility

- o Test lever reachable
- Visual inspection

Clear discharge path

3. Orientation

- o Stem horizontal maximum
- Never downward
- o Discharge downward

Prohibited Installations:

- Below top 6" of tank
- With shutoff valve between
- Reduced fittings
- Concealed locations

Discharge Piping Requirements

Code Requirements:

Material:

Approved Materials:

- Copper
- CPVC (temperature rated)
- Galvanized steel
- Listed relief piping

Installation Specifications:

Requirements:

- Size: ≥ relief valve outlet
- Termination: 6" above floor
- Slope: Continuous downward
- Support: Every 4 feet
- No traps or low points

Termination:

- Visible location
- Not threaded
- No caps/plugs/valves
- Air gap required
- Safe discharge location

Length Limitations:

- Minimize length
- Reduce elbows
- Consider back pressure
- Size for flow capacity

Testing Procedures

Manual Test:

Frequency:

- Annually minimum
- After installation
- After service
- If discharge observed

Procedure:

- 1. Warn occupants
- 2. Position bucket
- 3. Lift test lever fully
- 4. Hold 5 seconds
- 5. Release lever
- 6. Verify water flow
- 7. Check complete closure
- 8. No continued dripping

What to Check:

- Smooth operation
- Full flow when open
- Complete shutoff
- No corrosion/deposits
- Discharge piping clear

Safety Precautions:

- Hot water discharge
- Full pressure/flow
- Proper drainage
- Stand clear
- PPE recommended

Replacement Criteria

Replace When:

1. Failed Test

- o Won't open manually
- o Won't close completely
- o Restricted flow
- Continuous dripping

2. Physical Damage

- Corrosion visible
- o Damaged test lever
- Missing components
- o Impact damage

3. Age/History

- o Over 5 years old
- History of problems
- o After tank replacement
- o Unknown condition

Replacement Procedure:

- 1. Shut off gas and water
- 2. Drain tank partially
- 3. Remove discharge piping
- 4. Unscrew old valve
- 5. Clean threads
- 6. Apply tape/compound
- 7. Install new valve
- 8. Hand tight plus 3 turns
- 9. Reconnect discharge
- 10. Fill and test

Selection Criteria:

- Match BTU rating
- Correct pressure (150 PSI)
- Correct temperature (210°F)
- Proper connection size
- AGA/CSA approved

Documentation:

- Date of replacement
- Valve specifications
- Test results
- Next test date
- Technician name

16.7 Water Heater Maintenance

Anode Rod Inspection/Replacement

Inspection Schedule:

Age | Frequency 0-2 years | Initial inspection

2-5 years | Annual 5-8 years | Semi-annual 8+ years | Quarterly or replace

Inspection Procedure:

1. Preparation

- Turn off power/gas
- Turn off cold water
- o Relieve pressure
- May need to drain partially

2. Removal

- Locate anode (top usually)
- o Use 1-1/16" socket typical
- Break loose carefully
- May need impact wrench

3. Inspection Points

- o Measure remaining diameter
- o Check core wire exposure
- Note calcium deposits
- Assess consumption pattern

Replacement Criteria:

- 50% or more consumed
- Core wire exposed 6"+
- Heavy calcification
- Tank over 5 years
- Water quality issues

Installation Tips:

- Use Teflon tape only
- Don't overtighten
- Consider flexible anode
- Check clearance first
- Document replacement

Tank Flushing

Purpose: Remove sediment accumulation that reduces efficiency and capacity.

Frequency:

Water Hardness | Flush Schedule

```
Soft (0-3 gpg) | Annual
Medium (4-7) | Semi-annual
Hard (8-12) | Quarterly
Very Hard (13+) | Bi-monthly
```

Flushing Procedure:

1. **Setup**

- o Turn off heater
- o Turn off cold supply
- Attach hose to drain
- o Route to safe location

2. Flush Process

- o Open drain valve fully
- o Open T&P valve (air inlet)
- o Drain completely
- Note sediment amount

3. Refill

- o Close drain valve
- o Close T&P valve
- Open cold supply
- o Purge air from hot taps
- Restart heater

Power Flush Method:

- Leave cold water on
- Creates turbulence
- Better sediment removal
- Watch for clear water

Combustion Chamber Inspection

Visual Inspection:

Access:

- Remove outer door
- Remove inner door (if present)
- Use flashlight/mirror

Check For:

- Rust/corrosion
- Soot accumulation
- Debris/lint
- Burn patterns

• Damaged components

Cleaning:

- 1. Vacuum loose debris
- 2. Brush chamber walls
- 3. Clean viewport
- 4. Check gaskets
- 5. Reassemble properly

Warning Signs:

- Heavy soot (combustion issue)
- Rust flakes (tank concern)
- Melted components (overfire)
- Water stains (leak)

Burner Cleaning

Atmospheric Burner:

Cleaning Steps:

- 1. Remove burner assembly
- 2. Brush burner ports
- 3. Clear orifice
- 4. Check air shutter
- 5. Vacuum chamber
- 6. Reinstall and align

Inspection Points:

- Port blockage
- Rust/corrosion
- Proper flame pattern
- Air adjustment
- Secure mounting

Power Burner:

Maintenance:

- 1. Clean air intake screen
- 2. Check blower wheel
- 3. Inspect gaskets
- 4. Test pressure switch

- 5. Clean flame sensor
- 6. Verify combustion

Vent System Inspection

Annual Inspection Points:

Draft Hood (Atmospheric):

- Proper alignment
- No obstructions
- Corrosion check
- Spillage signs
- Support adequate

B-Vent System:

- Joint integrity
- Support spacing
- Clearances maintained
- Termination condition
- No disconnections

Power Vent:

- Blower operation
- Bearing noise
- Intake screen clean
- Exhaust clear
- Gaskets intact

Direct Vent:

- Termination screens
- Snow/ice clearance
- Pipe support
- Joint integrity
- Condensate drainage

Draft Test:

- Use smoke/match
- Check spillage
- Verify draft
- Test worst-case
- Document results

Relief Valve Testing

Test Procedure:

Monthly Quick Test:

- 1. Lift lever partially
- 2. Hear water flow
- 3. Release lever
- 4. Verify shutoff

Annual Full Test:

- 1. Full lever lift
- 2. Full flow discharge
- 3. 5-second duration
- 4. Complete closure
- 5. No dripping after

Documentation:

Test Record:
Date:
Result: Pass/Fail
Flow: Good/Restricted

Closure: Complete/Dripping

Action: None/Replaced

Tech: _____

16.8 Troubleshooting Water Heaters

No Hot Water

Diagnostic Process:

Step 1: Verify Utilities

- Gas supply on?
- Gas valve open?
- Electrical power present?
- Water supply on?

Step 2: Check Pilot/Ignition

Standing Pilot:

Checks:

- 1. Pilot lit? \rightarrow Relight
- 2. Thermocouple voltage (25-30mV)
- 3. Pilot flame engulfing thermocouple
- 4. Gas control valve function

Electronic Ignition:

Checks:

- 1. Power to control
- 2. Igniter operation
- 3. Gas valve opening
- 4. Flame sense signal
- 5. Error codes

Step 3: Main Burner Operation

- Thermostat calling?
- Gas valve opening?
- Proper gas pressure?
- Flame established?

Common Causes:

- 1. Pilot outage
- 2. Faulty thermocouple
- 3. Bad gas control valve
- 4. No gas supply
- 5. Tripped ECO

Insufficient Hot Water

Systematic Diagnosis:

Verify Demand vs. Capacity:

Questions:

- Recent usage increase?
- More occupants?
- New fixtures?
- Simultaneous use?

Check Temperature Setting:

- Current setting (120°F typical)
- Adjust if needed
- Test actual temperature
- Compare to setpoint

Dip Tube Inspection:

- Cold water entering top?
- Plastic particles in fixtures?
- Manufactured 1993-1997?
- Short cycling?

Recovery Rate Issues:

Tests:

- 1. BTU input correct?
- 2. Gas pressure adequate?
- 3. Burner clean?
- 4. Venting proper?
- 5. Combustion air sufficient?

Tank Capacity Loss:

- Sediment accumulation
- Scale buildup
- Perform flush
- Check anode rod

Temperature Issues

Water Too Hot:

Diagnosis:

- 1. Check thermostat setting
- 2. Test actual temperature
- 3. Verify thermostat operation
- 4. Check for stacking
- 5. Test ECO function

Solutions:

- Adjust thermostat
- Replace if faulty
- Install mixing valve
- Reduce setting
- Check for crossed connections

Water Not Hot Enough:

Diagnosis:

- 1. Thermostat setting low?
- 2. High demand periods?
- 3. Mixing valve set low?
- 4. Thermostat faulty?
- 5. Low gas input?

Solutions:

- Increase setting (max 140°F)
- Upgrade heater size
- Adjust mixing valve
- Replace thermostat
- Check gas pressure

Temperature Fluctuation:

Causes:

- Tankless: Cold water sandwich
- Tank: Stacking effect
- Crossed connections
- Mixing valve issues
- Pressure variations

Pilot Outage Problems

Frequent Pilot Outage:

Diagnostic Steps:

- 1. Draft Issues
 - o Downdrafts?
 - o Negative pressure?
 - o Vent blockage?

2. Thermocouple Problems

- o Low voltage (<20mV)
- Poor connection
- Wrong position
- Needs replacement

3. Gas Issues

- Low pressure
- Contamination
- Wrong orifice
- o Air in line

Solutions by Cause:

Draft Problems:

- Check vent system
- Test for spillage
- Install draft hood
- Correct vent size
- Clear obstructions

Component Issues:

- Replace thermocouple
- Clean pilot assembly
- Adjust pilot flame
- Replace gas valve
- Tighten connections

Burner Problems

Yellow/Orange Flames:

Causes:

- Insufficient air
- Dust/lint in air
- Wrong orifice
- Low gas pressure
- Misalignment

Corrections:

- 1. Adjust air shutter
- 2. Clean burner ports
- 3. Verify orifice size
- 4. Check gas pressure
- 5. Realign burner

Delayed Ignition:

Symptoms:

- Puff-back on ignition
- Loud ignition
- Roll-out potential

Causes:

- Weak pilot
- Dirty burner
- Low gas pressure
- Poor air mixture

Noisy Operation:

Rumbling:

- Scale on tank bottom
- Sediment buildup
- Flush tank

Whistling:

- Restricted orifice
- Gas pressure high
- Clean or replace

Popping:

- Condensation dripping
- Scale flaking
- Normal in some cases

Vent Spillage

Detection Methods:

- 1. Visual:
 - Moisture around draft hood
 - o Rust on top of heater
 - Melted plastics nearby
- 2. Match/Smoke Test:
 - Hold at draft hood
 - Should draw upward
 - o Test worst-case
- 3. CO Testing:
 - o Ambient CO levels
 - o Check during operation
 - o Spillage indicates CO

Common Causes:

Blocked Vent:

- Bird nests
- Debris
- Disconnected sections
- Crushed pipe

Insufficient Draft:

- Undersized vent
- Too many elbows
- Horizontal runs
- No rise

House Depressurization:

- Exhaust fans
- Clothes dryer
- Fireplace
- HVAC returns

Solutions:

- 1. Clear obstructions
- 2. Resize vent if needed
- 3. Improve combustion air
- 4. Power vent conversion
- 5. Address house pressure

Relief Valve Discharge

Continuous Dripping:

Causes:

- Thermal expansion
- High water pressure
- Faulty valve
- Debris in seat

Diagnosis:

- 1. Check system pressure
- 2. Test with gauge
- 3. Check for expansion tank
- 4. Inspect valve seat

Solutions:

- Install expansion tank
- Install PRV if >80 PSI
- Replace relief valve
- Clean or replace

Intermittent Discharge:

During Heating:

- Normal expansion
- Install expansion tank
- Check for closed system

Random Times:

- Pressure spikes
- Water hammer
- PRV failing

Noise and Odor Issues

Common Noises:

Sizzling:

- Condensation on burner
- Normal during startup
- Check for leaks

Hammering:

- Water hammer
- Install arrestors
- Secure piping

Ticking:

- Thermal expansion
- Heat traps
- Usually normal

Gurgling:

- Sediment boiling
- Flush tank
- Check temperature

Odor Problems:

Rotten Egg Smell:

- Bacteria in tank
- Anode rod reaction
- Well water common

Solutions:

- 1. Chlorinate tank
- 2. Replace with zinc anode
- 3. Increase temperature temporarily
- 4. Install filtration

Gas Smell:

- Check connections
- Soap test fittings
- Ventilate area
- Call gas company if strong

Chapter Review

Key Concepts Summary

1. Water Heater Types

- o Atmospheric: Simple, reliable, natural draft
- o Power vent: Flexible venting, forced exhaust
- o Direct vent: Sealed combustion, safest
- o Tankless: On-demand, high efficiency
- o Condensing: Highest efficiency, PVC venting

2. Critical Components

- o Anode rod protects tank from corrosion
- o T&P valve prevents catastrophic failure
- o Proper venting ensures safe operation
- o Gas controls maintain temperature
- o Dip tube promotes stratification

3. Installation Requirements

- o Follow CSA B149.1 code requirements
- Proper clearances mandatory
- o Adequate combustion air critical
- o T&P discharge must be visible
- Seismic strapping where required

4. Sizing Principles

- o First Hour Rating for storage tanks
- o Flow rate and temperature rise for tankless
- o Consider peak demand periods
- o Account for future needs
- o Regional temperature variations

5. Maintenance Importance

- o Annual anode rod inspection
- Regular tank flushing
- o T&P valve testing
- Vent system inspection
- o Extends equipment life significantly

Sizing Calculations

Exercise 1: Storage Tank Sizing

```
Family of 5, morning peak:
    4 showers × 15 gal = 60 gal
    2 sinks × 3 gal = 6 gal
    1 dishwasher = 8 gal
Total = 74 gallons

Solution:
75-gallon tank or
50-gallon with high recovery
```

Exercise 2: Tankless Sizing

```
Simultaneous use:
- 2 showers at 2.5 GPM = 5.0 GPM
- 1 sink at 1.5 GPM = 1.5 GPM
Total = 6.5 GPM

Temperature rise:
120°F - 45°F = 75°F

Required: 7+ GPM at 75°F rise
Select: 180,000 BTU/h unit
```

Exercise 3: Recovery Rate

```
Given:
50,000 BTU/h input
75% efficiency
100°F temperature rise

Recovery = (50,000 × 0.75) ÷ (8.33 × 100)
Recovery = 37,500 ÷ 833
Recovery = 45 GPH
```

Installation Planning Exercises

Scenario 1: Basement Installation

Requirements: - Atmospheric 50-gallon - Concrete floor - 8' ceiling - B-vent available Plan: - Clearances: 1" sides/back - Combustion air: Two openings - Vent: Connect to existing - T&P: Discharge to floor drain - Gas: 1/2" with drip leg

Scenario 2: Tankless Replacement

Existing: 40-gallon atmospheric
New: Condensing tankless

Modifications needed:
- Increase gas line to 3/4"
- Install PVC venting
- Add condensate drain
- Electrical for controls
- Water softener recommended

Code Compliance Checks

Checklist for Installation:

1.	Location	
	0	[] Not in bedroom (unless direct vent)
	0	[] Accessible for service
	0	[] Proper floor protection
	0	[] Required elevation (garage)
2.	Clear	ances
	0	[] Manufacturer specifications
	0	[] Service access maintained
	0	[] Vent connector clearances
	0	[] Combustibles protected
3.	Venting	
	0	[] Proper category
	0	[] Correct sizing
	0	[] Proper termination
	0	[] Required clearances
4.	Gas P	iping
	0	[] Proper sizing

[] Shutoff valve
[] Union installed
[] Drip leg present
5. Safety Devices
[] T&P valve installed
[] Discharge piping compliant
[] Vacuum relief (if needed)
[] Seismic strapping (if required)

Diagnostic Scenarios

Scenario 1: No Hot Water - Atmospheric

Symptom: No hot water, pilot out

Tests: Thermocouple 10mV
Diagnosis: Weak thermocouple
Solution: Replace thermocouple

Scenario 2: Insufficient Hot Water

Symptom: Runs out quickly Found: 1995 manufacture date Tests: Plastic in aerators Diagnosis: Broken dip tube

Solution: Replace dip tube or heater

Scenario 3: Relief Valve Dripping

Symptom: Constant drip from T&P Tests: Water pressure 95 PSI Diagnosis: High system pressure

Solution: Install PRV and expansion tank

Scenario 4: Yellow Flames

Symptom: Yellow burner flames Found: Lint on air shutter Tests: Clean and adjust

Diagnosis: Insufficient primary air Solution: Clean and adjust air shutter

Scenario 5: Pilot Won't Stay Lit

Symptom: Pilot lights but goes out Tests: Draft at draft hood OK Found: Thermocouple not in flame

Diagnosis: Mispositioned thermocouple

Solution: Adjust position

Scenario 6: Tankless Error Code

Symptom: Error code 11 Manual: Ignition failure Tests: Gas pressure 3" W.C. Diagnosis: Low gas pressure Solution: Upsize gas line

Scenario 7: Rumbling Noise

Symptom: Rumbling during heating

Found: Hard water area Tests: Drain shows sediment Diagnosis: Sediment buildup

Solution: Flush tank, check anode

Scenario 8: Vent Spillage

Symptom: Moisture on top Tests: Failed spillage test Found: Bathroom fan running Diagnosis: Depressurization Solution: Provide combustion air

Scenario 9: Odor Complaints

Symptom: Sulfur smell in hot water

Found: Well water supply Tests: Only in hot water

Diagnosis: Bacteria/anode reaction Solution: Replace with zinc anode

Scenario 10: Temperature Fluctuation

Symptom: Varies hot to cold

Type: Tankless

Found: Low flow rates

Diagnosis: Below minimum flow Solution: Install recirculation

Scenario 11: Long Recovery Time

Symptom: Slow to reheat

Tests: Input only 28,000 BTU/h

Found: Wrong orifice

Diagnosis: LP orifice on NG

Solution: Install correct orifice

Scenario 12: Premature Failure

Symptom: 3-year-old tank leaking

Tests: Very low anode rod Found: Water softener set high Diagnosis: Aggressive water

Solution: Adjust softener, maintain anodes

Professional Best Practices

1. Safety First

- Test for gas leaks
- Verify proper venting
- o Test all safety devices
- Check CO levels
- Document conditions

2. Customer Education

- o Explain maintenance needs
- Demonstrate T&P testing
- Discuss temperature settings
- o Review efficiency options
- Provide documentation

3. Quality Installation

- Follow manufacturer instructions
- Meet or exceed code
- Use quality materials
- Plan for service access
- Consider future needs

4. Preventive Maintenance

- Schedule annual service
- Document all work
- Track component age
- o Anticipate replacements
- Maintain service history

Conclusion

Water heaters are essential appliances requiring proper selection, installation, and maintenance. Understanding various technologies—from simple atmospheric tanks to sophisticated condensing tankless units—enables technicians to provide appropriate solutions for each application.

Key principles for success:

- Safety always takes priority
- Proper sizing ensures satisfaction
- Code compliance is non-negotiable
- Regular maintenance extends life
- Systematic troubleshooting solves problems
- Customer education prevents issues

As water heating technology advances with smart controls, hybrid systems, and improved efficiency, fundamental principles of safe gas combustion, proper venting, and

temperature/pressure safety remain constant. Professional technicians must maintain current knowledge while mastering these timeless fundamentals.