




Canadian Gas Technician Learning Module 9 Introduction to Gas Appliances

Learning Objectives


Upon completion of this chapter, students will be able to:

1. Identify major categories of gas appliances and their applications
2. Interpret appliance rating plates and certification markings
3. Distinguish between venting categories and select appropriate venting
4. Calculate and apply input ratings, including de-rating requirements
5. Understand efficiency ratings (AFUE, thermal, combustion)
6. Apply clearance requirements to combustibles per CSA B149.1
7. Calculate combustion air requirements for appliances
8. Install appliances according to manufacturer instructions and code
9. Perform initial commissioning and testing of gas appliances
10. Document appliance installations properly

9.1 Appliance Categories

Gas appliances convert the chemical energy in natural gas or propane into useful heat for various applications.

Heating Equipment



Central Heating:

Forced Air Furnaces:

- Most common residential heating
- Heat exchanger plus blower
- Ducted air distribution
- 40,000 150,000 BTU/hr residential
- Up to millions BTU commercial
- Various efficiency levels (80-98% AFUE)

Boilers (Hydronic Heating):

- Heat water or produce steam
- Radiant heat distribution
- Baseboards, radiators, or in-floor
- 50,000 400,000 BTU/hr residential
- Larger for commercial/industrial
- 80-95%+ efficiency

Unit Heaters:

- Self-contained heating unit
- Direct space heating
- Common in garages, warehouses, shops
- 30,000 400,000 BTU/hr typical
- Vented or unvented (separated combustion)



Space Heaters:

Vented Space Heaters:

- Wall-mounted or floor-standing
- Direct vented or B-vented
- Zone heating
- 10,000 40,000 BTU/hr typical
- Supplemental heat

Vent-Free Space Heaters:

- No venting required
- Restrictions in Canada (limited or prohibited in some jurisdictions)
- Oxygen depletion sensor required
- Maximum size limitations
- CSA B149.1 restrictions

Infrared Heaters:

- Radiant heat
- High-intensity or low-intensity
- Industrial/commercial applications
- Outdoor heating (patios)
- Vented or unvented designs



Water Heating

Storage Tank Water Heaters:

- Most common residential
- 30-75 gallon capacity typical
- 30,000 75,000 BTU/hr input
- Various venting types
- Recovery rate important

Tankless (Instantaneous) Water Heaters:

- Heat water on demand
- No storage tank
- 120,000 199,000 BTU/hr residential
- Continuous hot water
- Higher efficiency potential
- Complex installation requirements

Commercial Water Heaters:

- Larger capacity storage
- Higher input rates
- Multiple units common
- Specialized applications

Indirect Water Heaters:

- Tank heated by boiler
- No direct gas burner
- Very efficient
- Common with hydronic systems



Cooking Appliances



Ranges:

- Combined cooktop and oven
- 30" and 36" widths common
- 65,000 75,000 BTU/hr typical total input
- Open burner or sealed burner



Wall Ovens:

- Built-in ovens separate from cooktop
- Single or double ovens
- 18,000 25,000 BTU/hr each
- Convection or conventional



Cooktops:

- Counter-mounted burners only
- 4-6 burners typical
- 30,000 45,000 BTU/hr
- Various burner configurations

Commercial Cooking Equipment:

- Ranges (heavy-duty)
- Griddles
- Fryers
- Ovens (standard and convection)
- Broilers
- Specialized equipment
- Much higher inputs than residential



Clothes Dryers

1

Residential Dryers:

- 30,000 35,000 BTU/hr input
- Vented to exterior
- Moisture removal
- Gas or electric ignition

2

Commercial Dryers:

- Laundromats and institutions
- Higher capacity
- 100,000+ BTU/hr
- Multiple units common

Other Appliances



Fireplaces and Fireplace Inserts:

- Decorative and/or heating
- Vented or vent-free (where permitted)
- Direct vent popular
- Gas logs in existing fireplaces
- 20,000 40,000 BTU/hr typical



Pool and Spa Heaters:

- Outdoor installation typical
- 100,000 400,000 BTU/hr
- Weatherproof construction
- Corrosion-resistant materials




Outdoor Appliances:

- Patio heaters
- Barbecues (built-in)
- Outdoor fireplaces
- Fire pits
- Weather-resistant construction



Generators (Standby):

- Emergency power
- Engine-driven
- Automatic start
- Whole-house or partial
- Varies greatly in size



9.2 Venting Categories

Appliances are classified by venting method, which affects installation requirements.

Category I Appliances

Characteristics:



Draft hood equipped (natural draft)



Non-positive vent static pressure



Flue gas temperature > 140°F (60°C)



Non-condensing



Traditional design

Operation:

- Natural draft pulls combustion products through heat exchanger
- Draft hood dilutes flue gases with room air
- Creates negative pressure in vent
- Relies on buoyancy

Venting:

- Type B gas vent (double-wall)
- Single-wall vent connector (limited length)
- Vertical termination through roof
- Cannot use PVC or plastic
- Must terminate above roof per code

Efficiency:

- 78-82% AFUE typical
- Heat lost in flue gases
- Draft hood allows spillage potential



Examples:

- Older furnaces
- Atmospheric water heaters
- Standard boilers
- Most cooking appliances

Installation Considerations:

1

Adequate combustion air critical

2

**Building depressurization can
cause spillage**

3

**Vent must be properly sized and
installed**

4

Draft must be adequate

5

Spillage testing required

Category II Appliances

Characteristics:

- Non-positive vent static pressure
- Flue gas temperature $\leq 140^{\circ}\text{F}$ (60°C)
- May condense in vent
- Rarely seen (few manufacturers)

Venting:

- Special vent materials
- Corrosion-resistant
- Must handle condensation
- Specific to appliance

Notes:

- ❏ **Category II appliances are uncommon.** This category is mostly a historical reference. Always check specific appliance requirements if you encounter one.

Category III Appliances

Characteristics:

Positive vent static pressure

Flue gas temperature > 140°F (60°C)

Forced or induced draft

Non-condensing

Power vented

Operation:

- Fan forces or induces draft
- Creates positive pressure in vent
- No draft hood
- More efficient than Category I

Venting:


- Special vent materials
- Single-wall metal or specific listed materials
- Can vent horizontally through wall
- Shorter vent runs possible
- Must withstand positive pressure

Examples:

- Some power-vented water heaters
- Older power-vented furnaces
- Commercial equipment

Installation:

- Follow manufacturer specifications exactly
- Electrical interlock required (vent fan)
- Vent material critical
- Termination specific to appliance



Category IV Appliances

Characteristics:

Positive vent static pressure	Flue gas temperature $\leq 140^{\circ}\text{F}$ (60°C)	Condensing
High efficiency	Forced or induced draft	

Operation:

- Extracts maximum heat from combustion
- Flue gases cooled below water vapor condensation point
- Water vapor condenses in heat exchanger
- Latent heat recovered
- Fan creates positive vent pressure


Venting:

- PVC, CPVC, or ABS plastic (per manufacturer)
- Polypropylene
- Stainless steel
- Must resist condensate (acidic)
- Can vent horizontally through wall
- Direct vent option

Efficiency:

- **90-98% AFUE**
- Highest efficiency category
- Condensate produced (must be drained)

CONDENSATION IN A HIGH-EFFICIENCY FURNACE



Examples:

- High-efficiency furnaces (90%+)
- High-efficiency boilers
- Condensing tankless water heaters
- Modern residential equipment

Installation:




Condensate drain required



Must pitch for drainage




PVC primer and cement per manufacturer



Air intake often incorporated



Specific termination requirements



Electrical interlock

Condensate Management:

- Drain to floor drain, condensate pump, or outside
- May require neutralization (depending on local code)
- Trap required per manufacturer
- Cannot freeze
- Approximately 1 gallon per 100,000 BTU input

Direct Vent Appliances



Not a numbered category, but common design

Characteristics:

- Sealed combustion chamber
- Concentric vent (pipe within pipe)
- Combustion air drawn from outside
- Flue gases exhausted outside
- No room air used for combustion

Operation:

- Outer pipe brings combustion air in
- Inner pipe exhausts flue gases out
- Completely isolated from indoor air
- Can be Category III or IV



Venting:

- Horizontal through wall (most common)
- Vertical through roof (possible)
- Concentric termination
- Specific clearances to openings

Advantages:

No combustion air from indoors (tight buildings)

No spillage potential

Can install in confined spaces

More flexible installation

Examples:

- Direct vent fireplaces
- Direct vent water heaters
- Some furnaces
- Wall furnaces

Installation:

- Follow manufacturer termination requirements exactly
- Clearances to openings critical
- Must maintain slope for drainage
- Seal penetration properly

Power Vent vs. Direct Vent

Power Vent:

- Uses indoor air for combustion
- Vents through power vent fan
- Single pipe exhaust
- Separate combustion air from room

Direct Vent:

- Uses outdoor air for combustion
- Sealed combustion
- Concentric vent (usually)
- No room air involved



9.3 Certification and Approval

All gas appliances must be certified for use in Canada.

Certification Marks



CSA (Canadian Standards Association):

- Most common certification in Canada
- Blue CSA mark with flame logo
- Indicates compliance with Canadian standards
- Tested for safety
- Different marks for different products



UL/ULC (Underwriters Laboratories):

- Safety certification
- Both U.S. (UL) and Canadian (ULC) marks
- Some appliances carry both CSA and ULC



AGA (American Gas Association) / CGA (Canadian Gas Association):

- Blue star seal
- Certifies performance
- Common on cooking appliances
- Now mostly replaced by CSA



ANSI (American National Standards Institute):


- Standards reference
- Not certification mark itself
- Standards adopted by certifying bodies

Requirements:

- Must have recognized certification mark
- Installed per listing and manufacturer instructions
- Uncertified appliances not permitted
- Used appliances must retain certification marking

Rating Plate Information

Required Information on Rating Plate:



01

Manufacturer Name and Model Number

- Identifies appliance
- Required for service
- Parts ordering

02

Certification Mark

- CSA, AGA/CGA, ULC
- Confirms approval

03

Gas Type

- Natural gas or propane (LP)
- May show both if convertible
- Critical for proper operation

01

Input Rating

- BTU/hr or kW
- Manifold pressure
- Orifice size (sometimes)

02

Elevation (De-rating)

- Maximum elevation without de-rating
- De-rating requirements if applicable
- Important in mountainous areas

03

Electrical Requirements

- Voltage (115V, 230V typical)
- Amperage
- Must match supply

01

Venting Information

- Category (I, III, IV)
- Vent material requirements
- Vent diameter
- Maximum/minimum vent length

03

Serial Number

- Unique identifier
- Manufacturing date (encoded)
- Warranty reference

02

Clearances

- Minimum clearances to combustibles
- Required for safe installation

04

Other:

- Efficiency rating (AFUE for furnaces/boilers)
- For water heaters: recovery rate, first hour rating
- Special instructions or warnings

Interpreting Rating Plates

Example Furnace Rating Plate:

Manufacturer: XYZ Heating Company
Model: ABC-100
Serial: 12345678
Certification: [CSA Logo]
Gas Type: Natural Gas (NAT) - Propane (LP) Field Convertible
Input: 100,000 BTU/hr NAT @ 3.5" W.C.
100,000 BTU/hr LP @ 10" W.C.
Output: 95,000 BTU/hr (95% AFUE)
Electrical: 115V / 60Hz / 15A
Venting: Category IV, PVC Sch 40, 3" diameter
Max Vent Length: 60 ft equivalent
Clearances: Front: 24" for service
Sides: 3" to combustibles
Rear: 1" to combustibles
Top: 12" to combustibles
Flue: 1" clearance
Elevation: Suitable for use up to 2000 ft (600 m)
See manual for de-rating above 2000 ft
For installation and service, see manual provided

Reading This Plate:

- High-efficiency condensing furnace (Category IV, 95% AFUE)
- 100,000 BTU input, 95,000 BTU output
- Requires 3" PVC vent
- Can burn either natural gas or propane (with conversion)
- Different manifold pressures for each fuel
- Needs 115V electrical
- Specific clearances must be maintained
- De-rating required above 2000 feet elevation

9.4 Input Rating and Efficiency

Understanding input, output, and efficiency is essential for proper appliance selection and operation.

Input Rating

Definition:

- Rate at which appliance consumes fuel
- Measured in BTU/hr (or kW in metric)
- Based on heating value of gas
- Total energy entering appliance

Determining Input:

- Stamped on rating plate
- Can calculate: (gas flow in CFH) $\times$ (heating value)
- Natural gas: CFH $\times$ 1,000 BTU/ft³
- Propane: CFH $\times$ 2,500 BTU/ft³

Example:

- Gas flow: 100 ft³/hr natural gas
- Heating value: 1,000 BTU/ft³
- Input: $100 \times 1,000 = 100,000$ BTU/hr

MBH Notation:

- M = thousands (Roman numeral)
- BH = BTU/hr
- 100 MBH = 100,000 BTU/hr
- Common shorthand

Output Rating

Definition:

- Useful heat delivered by appliance
- Always less than input (losses occur)
- Measured in BTU/hr

Heat Losses:

- Up the vent (flue gases)
- Cycling losses
- Jacket losses (heat exchanger surface)
- Pilot light (standing pilot systems)

Example:

- Input: 100,000 BTU/hr
- Vent losses: 18,000 BTU/hr
- Cycling losses: 2,000 BTU/hr
- Output: 80,000 BTU/hr

Efficiency Ratings

AFUE (Annual Fuel Utilization Efficiency):

Used For:


- Furnaces
- Boilers
- Annual average efficiency

Includes:


- Steady-state efficiency
- Cycling losses
- Pilot light losses (if standing pilot)
- Jacket losses
- Real-world operation

Calculation:

- $(\text{Useful heat output} / \text{Energy input}) \times 100$
- Seasonal average, not instantaneous



Ranges:



Interpretation:

- 80% AFUE = 80% of fuel energy becomes useful heat
- 20% lost up vent and through cycling
- Higher AFUE = lower operating costs

Thermal Efficiency:

Used For:

- Water heaters
- Commercial equipment
- Steady-state measurement

Definition:

- Efficiency during continuous operation
- Does not include cycling or standby losses

Calculation:

- Similar to AFUE but steady-state only
- $(\text{Output} / \text{Input}) \times 100$

Ranges:

- Standard water heaters: 75-85%
- High-efficiency: 90-96%

Energy Factor (EF) for Water Heaters:

- Includes standby losses
- More comprehensive than thermal efficiency
- Replaced by Uniform Energy Factor (UEF) in newer ratings

Combustion Efficiency:

Definition:

- Efficiency of combustion process only
- Measured with combustion analyzer
- Stack loss calculation

Factors:

- Stack temperature
- Excess air (O_2 level)
- Fuel type

Use:

- Field measurement during service
- Verify proper combustion
- Tune-up indicator



Typical Values:

- Well-tuned atmospheric: 75-82%
- Power burners: 78-85%
- Condensing: 90-98%

Not Same as AFUE:

- AFUE includes cycling and other losses
- Combustion efficiency higher than AFUE
- Both important metrics

Capacity vs. Efficiency

Don't Confuse:

1

Input (capacity) = size

- High efficiency doesn't mean high capacity
- Can have small high-efficiency or large low-efficiency

2

Efficiency = percentage of fuel converted to useful heat

Example:

Furnace A:

- 60,000 BTU input
- 95% efficient
- = 57,000 BTU output

Furnace B:

- 100,000 BTU input
- 80% efficient
- = 80,000 BTU output

B has higher output despite lower efficiency (because larger input)

9.5 De-rating Requirements

Appliances must be de-rated (reduced input) in certain situations.


Altitude De-rating

Why Required:

- Air is thinner at higher elevations
- Less oxygen available for combustion
- Over-firing can occur if not de-rated
- Incomplete combustion risk

When Required:


- Check rating plate for maximum elevation
- Typically 2,000 feet (600 m) without de-rating
- Above this elevation, de-rate per manufacturer



De-rating Factors:

- Usually **4% reduction per 1,000 feet** above rated elevation
- Manufacturer specifications vary
- Some appliances altitude-compensating (no de-rating needed)

Example:



How to De-rate:

- Change orifices to smaller size
- Reduce manifold pressure
- Or combination
- Follow manufacturer instructions
- Document de-rating

Certification:

- De-rated appliances may need re-certification
- Check with authority having jurisdiction
- Maintain documentation

Propane Conversion De-rating

Why Sometimes Required:

- Propane has higher heating value (2,500 vs 1,000 BTU/ft³)
- Propane burns hotter
- Some appliances require de-rating when converted to propane

When Required:

- Check manufacturer conversion instructions
- Some appliances: same input both fuels
- Some appliances: must reduce input on propane
- Affects heat exchanger temperature

Example:

- Furnace: 100,000 BTU/hr on natural gas
- Conversion kit: de-rate to 85,000 BTU/hr on propane
- Smaller orifices AND lower manifold pressure
- Protects heat exchanger from overheating

Process:

- Follow conversion kit instructions exactly
- Change orifices
- Adjust manifold pressure
- May need different orifices than simple conversion would suggest
- Verify with combustion test

Load De-rating

Not Typically Required but Possible:

When Considered:

- Oversized equipment for load
- Cycling problems
- Comfort issues

Options:

- Reduce input by changing orifices
- Two-stage or modulating controls
- Proper sizing in first place (better)

Caution:

- ❏ **Load de-rating may void warranty and violate certification.**
Always consult manufacturer. Generally not recommended.

9.6 Installation Fundamentals

Proper installation is critical for safety, efficiency, and appliance longevity.

Manufacturer's Instructions

Critical Requirement:

- **Must follow manufacturer's installation instructions**
- Part of appliance certification
- Code requires compliance
- Provided with appliance

Instructions Include:

- Clearances to combustibles
- Venting requirements
- Combustion air requirements
- Gas connection specifications
- Electrical connection
- Specific installation steps
- Commissioning procedures

36 " GAS RANGE INSTALLATION INSTRUCTIONS



INSTALLATION AND SERVICE MUST BE PERFORMED BY
A QUALIFIED INSTALLER.
IMPORTANT: SAVE FOR LOCAL ELECTRICAL INSPECTOR'S USE.
READ AND SAVE THESE INSTRUCTIONS FOR FUTURE REFERENCE.

 **WARNING**

If the information in this manual is not followed exactly, a fire or explosion may result causing property damage, personal injury or death.

FOR YOUR SAFETY:

— Do not store or use gasoline or other flammable vapors and liquids in the vicinity of this or any other appliance.

— WHAT TO DO IF YOU SMELL GAS:

- Do not try to light any appliance.
- Do not touch any electrical switch; do not use any phone in your building.
- Immediately call your gas supplier from a neighbor's phone. Follow the gas supplier's instructions.
- If you cannot reach your gas supplier, call the fire department.

— Installation and service must be performed by a qualified installer, service agency or the gas supplier.

Appliances Installed in the state of Massachusetts:
This Appliance can only be installed in the state of Massachusetts by a Massachusetts licensed plumber or gasfitter.

This appliance must be installed with a 3 foot (36 in.) long flexible gas connector.

A "T" handle type manual gas valve must be installed in the gas supply line to this appliance.

Dimensions and Clearance
Provide adequate clearance between range and adjacent combustible surfaces.




Figure 1

NOTE: Wiring diagram for this appliance is enclosed in this booklet.
Printed in United States

P/N 318201759 (0605) Rev. C
English – pages 1-7
Español – páginas 8-15
Wiring Diagram – pages 16

If Instructions Lost:

- Download from manufacturer website
- Request from manufacturer
- Cannot install without instructions
- Required for inspection

Location Requirements

General Requirements:



Accessibility:

- Service access required
- Sufficient clearance for maintenance
- Door or panel access to controls
- Clearance for component removal



Protection:

- Protected from physical damage
- Not in traffic areas
- Protected from weather (if outdoor installation)
- Secure mounting



Ventilation:

- Adequate combustion air
- Room ventilation if required
- Not in sealed rooms (unless direct vent)
- Consider appliance requirements

CSA B149.1 Restrictions:

Not Permitted in:

- Bedrooms
- Bathrooms (with exceptions for direct vent)
- Closets (with exceptions)
- Storage rooms (with restrictions)
- Areas with corrosive atmosphere
- Locations subject to flooding

Permitted With Restrictions:

- Utility rooms (adequate combustion air)
- Basements (ventilation, protection from damage)
- Attics (accessibility, ventilation)
- Garages (elevated or protected from vehicle impact)
- Outdoors (weatherproof construction)

Support and Mounting



Floor-Standing:

- Level and stable
- Adequate floor support (structural capacity)
- Vibration isolation if needed
- Anchor if required by code or manufacturer




Wall-Mounted:

- Support adequate for weight
- Proper anchors for wall type
- Level installation
- No stress on gas connections



Suspended:

- Support from structure (not piping)
- Adequate hangers
- Seismic restraint (where required)
- Vibration isolation



9.7 Clearances to Combustibles

Clearances protect combustible materials from heat.

Why Clearances Required

Heat Transfer:

- Appliances generate heat
- Heat radiates and conducts
- Combustible materials can ignite
- Clearances provide safety margin

Combustible Materials:

- Wood framing
- Wood paneling
- Drywall (paper-faced)
- Plastic
- Insulation
- Carpet
- Most building materials

Non-Combustible:

- Concrete
- Masonry
- Steel
- Glass
- Ceramic tile

Clearance Requirements

Source of Requirements:

- Manufacturer specifications (primary)
- CSA B149.1 (code minimums)
- Most restrictive applies

Typical Clearances (Example Furnace):


- Front: 24-30" (service access)
- Sides: 3-6" to combustibles
- Rear: 1-3" to combustibles
- Top: 6-12" to combustibles
- Vent connector: 6" to combustibles (single-wall)

Zero-Clearance Appliances:

- Specifically designed and listed
- Can install against combustibles
- Follow manufacturer instructions exactly
- Common in fireplaces and inserts

Clearance Reduction Methods

When Clearances Cannot Be Met:



Never:

- Assume clearances can be reduced without approval
- Install closer than specified without proper protection
- Use unapproved protection materials
- Rely on insulation alone

9.8 Combustion Air Requirements

Adequate air is essential for safe and efficient combustion.

Air Requirements

Two Types of Air:

Combustion Air:

- Air for burning fuel
- Oxygen for combustion
- Consumed by appliance
- Exits through vent

Dilution/Ventilation Air:

- Air for draft hood dilution (Category I)
- Room ventilation
- Not consumed
- Mixes with room air

Total Air Requirements:

- Must provide both
- Calculations based on appliance input
- Location (confined vs. unconfined space)
- Inside or outside air source

Confined vs. Unconfined Space

Confined Space (CSA B149.1 Definition):

- Space with less than **1.5 m³ (50 ft³) per 1,000 BTU/hr** of total input
- Example: 100,000 BTU/hr appliance in room smaller than 150 m³ (5,000 ft³)
- Requires openings for combustion air

Unconfined Space:

- Space with **1.5 m³ (50 ft³) or more per 1,000 BTU/hr**
- Example: 100,000 BTU/hr appliance in room larger than 150 m³ (5,000 ft³)
- Generally has adequate infiltration (older buildings)
- May still need openings (tight buildings)

Modern Consideration:

- ❏ **Modern buildings are tight.** Even "unconfined" spaces may need openings. Best practice: provide dedicated combustion air. Direct vent appliances eliminate this concern.

Calculating Combustion Air Openings

CSA B149.1 Methods:

Method 1: All Air from Inside Building

Two Permanent Openings Required:

- One near ceiling
- One near floor
- Each opening minimum size based on appliance input

Sizing:

- Minimum 100 cm² per 10 kW (220 in² per 100,000 BTU/hr)
- If using single combustion air opening: double the size
- Openings to adjacent unconfined space

Example:

- Furnace: 100,000 BTU/hr
- Water heater: 40,000 BTU/hr
- Total: 140,000 BTU/hr
- Each opening: $140 \times 220 \div 100 = 308 \text{ in}^2$
- Convert: $308 \div 144 = 2.1 \text{ ft}^2 = \text{approximately } 18" \times 18"$

Method 2: All Air from Outdoors (Direct)

Two Permanent Openings:

- One near ceiling connected to outdoors
- One near floor connected to outdoors
- Each opening to outdoors

Sizing:

- Minimum 50 cm² per 10 kW (110 in² per 100,000 BTU/hr) if vertical ducts
- Minimum 100 cm² per 10 kW (220 in² per 100,000 BTU/hr) if horizontal ducts
- Smaller than indoor method (more effective)

Example:

- Total input: 140,000 BTU/hr
- Vertical ducts: each opening $140 \times 110 \div 100 = 154 \text{ in}^2 = 1.07 \text{ ft}^2$
- Approximately 12" x 12" each opening

Method 3: Mixed (One from Inside, One from Outside)

- Complex calculation
- Refer to CSA B149.1 tables
- Less common

Method 4: Mechanical Ventilation

- Powered ventilation
- Must provide adequate CFM
- Interlocked with appliances
- Requires engineering
- Special provisions per code


Combustion Air Duct Requirements

Material:

- Metal (galvanized steel typical)
- Minimum 26 gauge
- Sealed joints

Installation:

- Slope for drainage
- Screen at termination (1/4" mesh)
- No dampers or obstructions
- Protected from damage



Termination:

- Outdoors away from windows/doors
- Minimum 3 ft from forced air intakes
- Minimum 12" above grade (snow)
- Protected from wind (minimizes pressurization effects)

Maintenance Access:

- Cleanable
- Screens removable
- Periodic inspection required

Special Considerations

Direct Vent Appliances:

- Don't use room air
- No combustion air openings needed
- Sealed combustion
- Simplifies installation

Tight Buildings:

- Modern construction very tight
- Even unconfined spaces may need combustion air
- Exhaust fans create negative pressure
- Consider make-up air for exhaust systems

Depressurization:

- Exhaust fans (kitchen, bath, dryer)
- Central vacuum
- Fireplaces
- Can overcome natural draft
- Cause Category I spillage
- Direct vent or power vent eliminates this concern

Building Pressurization Test:

- Use manometer or draft gauge
- Measure pressure with exhaust equipment on
- -3 Pa (-0.01" W.C.) or more negative = concern
- May need make-up air or power-vented appliances

9.9 Appliance Inspection and Commissioning

Proper commissioning ensures safe and efficient operation.

Pre-Start Inspection

Visual Inspection:



Appliance:

- Physical damage during shipping or installation
- All covers and panels installed
- Access panels secure
- No loose parts



Electrical:

- Proper voltage supply
- Correct amperage circuit
- Ground wire connected
- No damaged wiring



Combustion Air:

- Openings adequate size
- Screens clean
- Ducts connected
- Not blocked



Gas Connection:

- Proper pipe size
- Shut-off valve accessible
- Drip leg installed (if required)
- All joints tight
- Leak tested



Venting:

- Proper material for category
- Correct diameter
- Proper slope (condensing appliances)
- No gaps or leaks
- Proper termination
- Clearances maintained



Clearances:

- Verified to combustibles
- No violations
- Proper protection if clearances reduced

Initial Start-Up Procedure

Step-by-Step:

01

Verify Gas Supply:

- Meter/tank has gas
- Service valve open
- Pressure adequate
- Appliance valve open

03

Observe Ignition:

- Pilot lights (if standing pilot)
- Igniter glows (if HSI)
- Spark visible (if DSI)
- Main burner ignites
- Time from call to ignition normal

05

Verify Blower/Pump Operation:

- Blower starts (furnace)
- Circulator runs (boiler)
- Appropriate delay
- Proper rotation
- No unusual noise

07

Temperature Rise (Furnaces):

- Measure supply air temperature
- Measure return air temperature
- Calculate rise: Supply – Return
- Compare to rating plate range
- Typical: 40-70°F rise

09

Cycle Test:

- Allow appliance to complete full cycle
- Verify proper shut-down
- Restart and verify operation
- Multiple cycles

02

Set Thermostat/Control:

- Call for heat/operation
- Manual mode if available
- Bypass delays if testing

04

Observe Flame:

- Proper flame characteristics
- Blue flame
- Stable
- No yellow tipping (or minimal)
- No lifting or flashback
- Even across burner

06

Check Pressure:

- Manifold pressure at rating plate value
- Inlet pressure adequate
- Adjust if needed

08

Combustion Testing:

- Insert probe in flue
- Allow readings to stabilize
- Record: O₂, CO₂, CO, stack temperature
- Calculate efficiency
- Verify acceptable limits

10

Safety Tests:

- Verify limits operate (test if possible)
- Verify pressure switches
- Check rollout switches
- Test flame sensor (simulate failure if possible)

Acceptance Criteria

Combustion:

- O₂: 5-9% typical
- **CO: < 100 ppm air-free (CSA B149.1)**
- CO₂: Natural gas 8-10%, Propane 10-12%
- Stack temperature: Per appliance type

Operation:

- Ignites reliably
- Burns steadily
- Proper flame appearance
- No unusual noise or vibration
- Controls function properly
- Safeties operate



Performance:

- Adequate heat output
- Temperature rise within range
- Pressure settings correct
- Efficiency acceptable

Safety:

- No gas leaks
- No spillage (Category I)
- No CO production in space
- All safeties function

Documentation

Record:

- Date and time of commissioning
- Manifold pressure
- Inlet pressure
- Combustion test results (all parameters)
- Temperature rise
- Any adjustments made
- Abnormalities noted
- Technician name and license
- Provide copy to customer

Customer Education:

Explain:



Operation

- How to operate appliance
- Thermostat/control use



Maintenance

- Filter changing (furnaces)
- Maintenance needs
- When to call for service



Safety

- Safety features
- Warning signs



Documentation

- Warranty information
- Keep records

Chapter Summary

Gas appliances convert fuel energy into useful heat through combustion. Major categories include heating equipment (furnaces, boilers, space heaters), water heaters (storage and tankless), cooking appliances, dryers, and specialty equipment (fireplaces, pool heaters, outdoor appliances). Each type has specific installation and performance characteristics.

Appliances are classified by venting category based on vent pressure and temperature. Category I (draft hood, non-condensing) requires Type B vent through roof. Category IV (positive pressure, condensing) uses PVC venting and achieves 90-98% efficiency by extracting latent heat from water vapor. Direct vent appliances use sealed combustion with outdoor air, eliminating spillage potential and combustion air requirements from living space.

All appliances must carry CSA, AGA/CGA, or ULC certification marks and rating plates showing input, gas type, electrical requirements, venting specifications, and clearances. Input ratings may require de-rating for high altitude (typically 4% per 1,000 feet above rated elevation) or propane conversion. Efficiency ratings include AFUE (annual average for furnaces and boilers), thermal efficiency (steady-state for water heaters), and combustion efficiency (field measurement).

Installation requires following manufacturer instructions for location, clearances to combustibles (reduced only with approved protection), and adequate combustion air. CSA B149.1 specifies calculation methods based on confined or unconfined space, with openings sized per total appliance input. Modern tight buildings often require dedicated combustion air even in apparently unconfined spaces.

Proper commissioning includes pre-start inspection, systematic start-up procedure, manifold pressure verification, combustion testing, and documentation. Acceptable combustion shows CO under 100 ppm air-free, proper O₂ and CO₂ levels, and efficient operation. Customer education on operation and maintenance completes the installation process.